CLAY TOWNSHIP CHILDREN'S PAVILION AT COXHALL

2000 W. 116TH STREET, CARMEL, IN 46032

HAMILTON COUNTY PARKS

BID DOCUMENTS APRIL 21, 2020

CONTACTS

ARCHITECTURE AND CIVIL ENGINEERING










LOCATION MAP



DRAWING INDEX

SHEET NAME

SHEET NUMBER

T001	TITLE SHEET
CIVIL	
C101	EXISTING CONDITIONS AND DEMOLITION PLANS
C201	SITE PLAN
C202	SITE AND UTILITY DETAILS
C301	GRADING PLAN
C401	STORMWATER POLLUTION PREVENTION PLAN
C402	STORMWATER POLLUTION PREVENTION PLAN DET.
C501	UTILITY PLAN
C701	STORM SEWER PLAN AND PROFILES
LANDSCAPE ARCHI	TECTURE
L100	PLANTING PLAN
L200	PLANTING PLAN
STRUCTURAL	
\$101	FOUNDATION PLAN
\$101A	ALTERNATE FOUNDATION PLAN
\$401	GENERAL NOTES SCHEDULES AND ABBREV
\$402	SLAB ON GRADE LEGEND
\$403	SECTIONS & DETAILS
\$600	MODEL VIEWS
ARCHITECTURE	
A101	FIRST FLOOR PLAN
A121	ALTERNATE METAL PERGOLA
A122	ALTERNATE CONCRETE SLABS
A123	MASONRY COLUMN WRAPS
A124	ALTERNATE MASONRY GRILLING AREAS
A201	REFLECTED CEILING PLAN
A401	ROOF PLAN
A501	EXTERIOR ELEVATIONS
A611	WALL SECTIONS

SHEET NUMBER SHEET NAME ELECTRICAL SYMBOLS AND ABBREVIATIONS ELECTRICAL DETAILS AND SCHEDULES FLOOR PLAN - ELECTRICAL

ELECTRICAL SPECIFICATIONS


METAL PERGOLA & ASSOCIATED WORK LEAF IMPRINTED CONCRETE SLAB EDGES

MASONRY KNEE WALLS & GRILLS & ASSOCIATED WORK

CONSULTANTS

12" = 1'-0" T00

2020/04/21 990433-10705



SS ——— SANITARY SEWER & MANHOLE POWER POLE GUY WIRE UTILITY RISER; TELEPHONE, ELECTRIC & CABLE TV ELECTRIC TRANSFORMER AIR CONDITIONER UNIT —— —E — —E —— ELECTRIC LINE (AERIAL) - STREET LIGHT - - \top - \top - \top - Telephone line (aerial) TRAFFIC MANHOLE AND SIGNAL POLE FIRE HYDRANT 🖄 🖄 VALVE; GAS & WATER STREET SIGN ₩ T E WATER, TELEPHONE AND ELECTRIC MANHOLE RIGHT OF WAY LINE (R/W) SEWER CLEANOUT PROPERTY LINE EMO GMO WMO ELECTRIC, GAS AND WATER METER EASEMENT LINE PIPELINE MARKER POST MAILBOX GUARD POST ⊗ SPRINKLER HEAD IRRIGATION CONTROL BOX SPOT GRADE TOP CURB/GUTTER GRADE MONITORING WELL FIRE SERVICE STAND PIPE GAS VENT PIPE SEPTIC TANK LID ₩C WELL CAP DENOTES A 5/8" DIA. REBAR WITH YELLOW PLASTIC CAP SET. AR RELIEF VALVE CAP STAMPED "CRIPE FIRM NO. 0055" UNLESS OTHERWISE NOTED. UNDERGROUND TANK FILLER PIPE DENOTES A MAG NAIL WITH WASHER SET. WASHER STAMPED 123 SITE ADDRESS "CRIPE FIRM NO. 0055" UNLESS OTHERWISE NOTED.

DEMOLITION PLAN LEGEND

SAWCUT AND REMOVE CONCRETE FROM SITE — CONSTRUCTION LIMITS TP TREE PRESERVATION FENCING

DEMOLITION PLAN NOTES

- 1. UTILITY LOCATIONS ARE APPROXIMATE. THE CONTRACTOR IS TO DETERMINE AND FIELD VERIFY ALL HORIZONTAL AND VERTICAL LOCATIONS OF THE UTILITIES PRIOR TO COMMENCEMENT OF CONSTRUCTION.
- THE CONTRACTOR SHALL COORDINATE ALL WORK ASSOCIATED WITH THE ABANDONMENT, REMOVAL, RELOCATION, AND INSTALLATION OF UTILITIES WITH EVERY UTILITY COMPANY AND OBTAIN THEIR APPROVAL
- 3. ALL DEMOLISHED MATERIAL TO BECOME THE PROPERTY OF THE CONTRACTOR UNLESS OTHERWISE NOTED,
- 4. CONTRACTOR SHALL INSTALL EROSION CONTROL MEASURES PER SHEET C401 PRIOR TO COMMENCING
- 6. SAWCUT CONCRETE AND ASPHALT SURFACES FOR REMOVAL AS NOTED.
- 7. THE CONTRACTOR SHALL BE RESPONSIBLE FOR REPAIRING DAMAGE TO ALL BUILDINGS AND/OR SITE
- 8. THE CONCRETE TO BE SAWCUT SHALL BE SAWCUT TO THE NEAREST CONCRETE JOINT BEYOND THE LIMITS ILLUSTRATED. NOTIFY ENGINEER IF JOINT IS OVER ONE (1) FOOT FROM LINE SHOWN.
- 9. REMOVAL OR RELOCATION OF ALL LANDSCAPING MUST BE COORDINATED WITH OWNER.
- PLACE MAY BE CUT AS NECESSARY TO FACILITATE NEW CONSTRUCTION. CONTRACTOR SHALL ENSURE THAT LINES ARE NOT ACTIVE PRIOR TO CUTTING AND OBTAIN UTILITY COMPANY APPROVAL PRIOR TO PERFORMING ANY
- INSTALLED TO A POINT SUCH THAT ONLY MINIMAL DISRUPTION IN WATER SERVICE TO THE EXISTING OCCUPIED BUILDINGS WILL OCCUR. CONTRACTOR TO COORDINATE ANY SERVICE SHUT DOWN WITH THE BUILDING OWNER AT LEAST 72 HOURS PRIOR TO SCHEDULING SHUT DOWN.
- BE BROUGHT TO THE ATTENTION OF THE ENGINEER IMMEDIATELY SO THAT CLARIFICATION OR REDESIGN
- 13. CONTRACTOR TO ESTABLISH NEW LOCAL SURVEY CONTROL SYSTEM (VERTICAL AND HORIZONTAL) PRIOR TO COMMENCEMENT OF CONSTRUCTION ACTIVITY. MANY TEMPORARY BENCHMARKS UTILIZED IN THE PREPARATION OF THE TOPOGRAPHIC SURVEY FOR THE DESIGN WILL BE RELOCATED AS PART OF

KEYNOTE LEGEND

- SAWCUT AND REMOVE CONCRETE SIDEWALK TO THE NEAREST CONCRETE JOINT BEYOND THE LIMITS
- REMOVE EXISTING DECORATIVE WALL TO INSTALL PIPING. WALL SHALL BE RE-INSTALLED AFTER STORM
- 4 REMOVE TREE, SHRUBS, UNDERBUSH, LANDSCAPING AND VEGETATION INCLUDING ROOT BALLS
- REMOVE EXISTING SIGN, POLE AND FOUNDATION. SIGNS SHALL BE REINSTALLED UPON COMPLETION

<u>CONSULTANTS</u>

₹ ± 1 •••••


Mal C. Ful

SDS Checked By: JCZ Quality Assurance:


1'' = 20' 2020/04/21


990433-10705


Project Number



2020/04/21







DUCTILE IRON GRATE

- ADAPTERS AVAILABLE 4" THRU 6"

VARIOUS TYPE OF OUTLETS WITH


POLYETHYLENE SCHEDULE 40 DWV


CORRUGATED PVC RIBBED PVC

TC = TOP OF CASTING ELEVATION


(SEE PLANS)

WATERTIGHT ADAPTORS FOR: SDR-35 SEWER CORRUGATED










** COMPACTED SUBGRADE * MINIMUM THICKNESS WHERE SIDEWALKS CROSS DRIVEWAYS, MINIMUM THICKNESS SHALL BE AS FOLLOWS: RESIDENTIAL: 6" FOR SIDEWALK, 6" FOR COMPACTED AGGREGATE #53 BASE COMMERCIAL/INDUSTRIAL: 8" FOR SIDEWALK, 8" FOR COMPACTED AGGREGATE #53 BASE.

- * 4" 4000 PSI 28 DAY CONCRETE


└─ 4" COMPACTED AGGREGATE #53 BASE

LIGHT BROOM FINISH

** COMPACTED SUBGRADE THE UPPER 6" SHALL COMPLY WITH THE DENSITY REQUIREMENTS OF THE TECHNICAL SPECIFICATIONS IMMEDIATELY PRIOR TO PLACING THE MATERIAL THEREON. ALL SOFT, YIELDING OR OTHER UNSUITABLE MATERIAL, WHICH CANNOT BE COMPACTED SATISFACTORILY, SHALL BE REMOVED. ALL ROCK ENCOUNTERED SHALL BE REMOVED OR BROKEN OFF AT LEAST 6" BELOW THE SUBGRADE SURFACE. ANY HOLES OR DEPRESSIONS RESULTING FROM THE REMOVAL OF UNSUITABLE MATERIAL SHALL BE FILLED WITH SATISFACTORY MATERIAL AND COMPACTED TO CONFORM WITH THE SURROUNDING SUBGRADE SURFACE.



ACCESSIBLE RAMP WITH CONCRETE FLARES NOT TO SCALE



DOWNSPOUT DRAIN (PVC) NOT TO SCALE

<u>CONSULTANTS</u>


Mal C. Hud

Drown By: SDS Checked By: JCZ Quality Assurance: DJP

1" = 20' 2020/04/21

990433-10705

Project Number



GRADING PLAN LEGEND ×800.00 PROPOSED GRADE

MEG MATCH EXISTING GRADE PROPOSED 5' CONTOUR TC 800.50 PROPOSED TOP OF CURB
PROPOSED EDGE OF PAVEMENT TW 800.50 PROPOSED TOP OF WALL PROPOSED BOTTOM OF WALL FFE=800.00 FINISHED FLOOR ELEVATION RE=800.00 RIM ELEVATION

FLOOD ROUTE PATH ── DRAINAGE FLOW ARROW

GRADING PLAN NOTES

- UTILITY LOCATIONS ARE APPROXIMATE. THE CONTRACTOR IS TO DETERMINE AND FIELD VERIFY ALL HORIZONTAL AND VERTICAL LOCATIONS OF THE UTILITIES PRIOR TO COMMENCEMENT OF CONSTRUCTION.
- 2. TOPOGRAPHIC AND PLANIMETRIC INFORMATION FROM PHOTOGRAPHIC COMPILATION HAS BEEN PROVIDED BY OTHERS. THE ACCURACY HAS NOT BEEN CONFIRMED BY CRIPE. ANY DISCREPANCIES SHALL BE REPORTED TO THE ENGINEER OF RECORD.
- 3. ALL GRADES AT BOUNDARY SHALL MEET EXISTING GRADES.
- 4. RIM ELEVATION (RE) SHALL INDICATE THE ELEVATION THAT WATER WOULD ENTER THE GRATE FOR ALL CASTINGS. IF CASTING HAS SOLID LID, THE RE IS THE LID ELEVATION.
- 5. BUILDING PAD AREAS AND PAVED AREAS DESIGNATED FOR FILL SHALL BE CONSTRUCTED OF SUITABLE FILL MATERIAL AND COMPACTED PER SPECIFICATIONS. ALL FILL AREAS SHALL BE STRIPPED OF TOPSOIL
- 6. ANY EXCESS SOIL MATERIAL SHALL BE EXPORTED FROM THE SITE AFTER CONSTRUCTION IS COMPLETED.
- 7. TOPSOIL SHALL BE PLACED IN LAWN, LANDSCAPE, MOUNDING AND NONSTRUCTURAL FILL AREAS. UPON COMPLETION OF MASS EARTHWORK, TOPSOIL SHALL BE SPREAD TO A DEPTH OF FOUR TO SIX (4 TO 6) INCHES IN AREAS LISTED ABOVE. TOPSOIL SHALL NOT BE UTILIZED AS STRUCTURAL FILL IN PAVED
- 8. CONTRACTOR SHALL PRESERVE EXISTING TREES WHEREVER POSSIBLE. CLEARING LIMITS SHALL CONSIST OF ALL TREES WITHIN PAVED AREAS, UTILITY INSTALLATION LIMITS, AND CUT/FILL AREAS.
- A GEOTECHNICAL REPORT HAS BEEN PROVIDED FOR THIS PROJECT FOR REFERENCE. CONTRACTOR TO REVIEW PRIOR TO START OF CONSTRUCTION.
- 10. A GEOTECHNICAL REPORT HAS NOT BEEN PROVIDED FOR THIS PROJECT. CONTRACTOR TO PERFORM A SITE VISIT PRIOR TO PROJECT BID. THE ENGINEER HAS BASED RECOMMENDATIONS UPON NRCS MAPS AND GENERAL KNOWLEDGE OF SOILS CONDITIONS IN THE AREA.
- 11. ANY DISCREPANCIES OR CONFLICTS WHICH BECOME APPARENT BEFORE OR DURING CONSTRUCTION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER OF RECORD IMMEDIATELY SO THAT CLARIFICATION OR REDESIGN MAY OCCUR.

FLOODPLAIN NOTES

- 1. THE SITE IS LOCATED WITHIN THE FLOOD HAZARD ZONE "AE" and "X" PER THE FLOOD INSURANCE RATE MAP, COMMUNITY PANEL NO. 18097C0159E, REVISED JANUARY 5, 2001.
- 2. THE 100 YEAR BASE FLOOD ELEVATION FOR THE SITE AS ILLUSTRATED ON THE FLOOD INSURANCE STUDY (FIS) PLATE NUMBER 30P FOR MARION COUNTY, INDIANA FOR FALCON CREEK XXX.X± ROUNDED UP TO THE NEAREST 0.5'.


<u>CONSULTANTS</u>

₹ ± 1 ••••••

SDS JCZ

1" = 20'

2020/04/21 990433-10705





STORMWATER POLLUTION PREVENTION PLAN LEGEND TP TP TP TREE PRESERVATION FENCING ss — ss — SILT SOCK — — CONSTRUCTION LIMITS TEMPORARY SEEDING GEOTEXTILE FABRIC YARD GEOTEXTILE FABRIC YARD DROP INLET PROTECTION INSERT (BAG) CURB INLET PROTECTION WITH CURB FILTER CONCRETE WASHOUT

STORMWATER POLLUTION PREVENTION PLAN NOTES

- 1. REFER TO SHEET **C40X** FOR SOILS MAP AND SOIL CHARACTERISTICS.
- 2. REFER TO SHEET **C40X** FOR STORMWATER POLLUTION PREVENTION PLAN DETAILS.
- 3. REFER TO LANDSCAPE PLANS FOR PLANTING DETAILS. ANY MOUNDING NOTED ON LANDSCAPE PLANS
- SHALL NOT CHANGE THE DRAINAGE PATTERN NOTED IN THE GRADING PLAN SERIES 300'S.
- 4. SILT FENCE BARRIER TO BE INSTALLED PRIOR TO CONSTRUCTION. 5. EROSION CONTROL MEASURES TO BE MAINTAINED THROUGHOUT THE ENTIRE CONSTRUCTION PROCESS.
- 6. REFER TO THE STORMWATER POLLUTION PREVENTIONS NOTES SHEET CXOX FOR ALL EROSION CONTROL
- MEASURES, SCHEDULES, AND SEQUENCES.
- CONTRACTOR TO PROVIDE A STABLE TEMPORARY GRAVEL CONSTRUCTION INGRESS/EGRESS CONDITION FROM THE CONSTRUCTION SITE TO KEEP MUD AND SEDIMENT OFF PUBLIC ROADS.
- 8. EROSION CONTROL MAINTENANCE SITE TO BE INSPECTED AT LEAST ONCE A WEEK AND MAKE REPAIRS IMMEDIATELY AFTER PERIODS OF 1/2" RAINFALL OR GREATER.
- 9. STORMWATER DISCHARGE WILL OR WILL NOT ENTER THE GROUNDWATER FOR THIS PROJECT.
- 10. THE 100 YEAR FLOODPLAIN FLOODWAYS ARE PRESENT AND LABELED ON THIS SITE OR NOT PRESENT.
- 11. PRESENCE OF HYDRIC SOILS: LIST TYPE.
- 12. CONTRACTOR SHALL PROVIDE THE DEPARTMENT OF BUSINESS & NEIGHBORHOOD SERVICES OF THE CITY OF INDIANAPOLIS WITH A NARRATIVE DESCRIBING THE CONSTRUCTION SEQUENCE, INCLUDING START DATES FOR EACH LAND DISTURBING ACTIVITY.
- 13. THE ACTUAL PERSON RESPONSIBLE FOR THE INSTALLATION AND MAINTENANCE OF THE EROSION CONTROL SHALL BE DETERMINED DURING THE BIDDING PROCESS. THE AWARD WINNING CONTRACTOR SHALL BE RESPONSIBLE FOR THE PROPER INSTALLATION AND MAINTENANCE OF ALL EROSION CONTROL MEASURES.
- ONCE DETERMINED, CONTRACTOR SHALL COORDINATE WITH THE CITY. 14. ANY DISCREPANCIES OR CONFLICTS WHICH BECOME APPARENT BEFORE OR DURING CONSTRUCTION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER OF RECORD IMMEDIATELY SO THAT CLARIFICATION OR

STORMWATER POLLUTION PREVENTION PLAN SEQUENCE AND IMPLEMENTATION

- INSTALL SILT FENCING. DUST SHALL BE KEPT TO A MINIMUM BY UTILIZING SPRINKLING WATER OR OTHER
- IDENTIFY CONSTRUCTION STAGING AREA, CONCRETE WASHOUT AREAS, MATERIAL STORAGE AND TOPSOIL STOCKPILE AREAS. EACH AREA SHALL BE PROPERLY PROTECTED AND DELINEATED PRIOR TO
- 3. THE IDEM NOI, IF REQUIRED, AND CONTACT INFORMATION FOR THE PERSON WITH ONSITE
- RESPONSIBILITIES MUST BE POSTED ONSITE.
- IDEM AND THE LOCAL CITY AGENCY MUST BE NOTIFIED WITHIN 48 HOURS OF COMMENCING CONSTRUCTION.
- 5. CONTACT INDIANA UNDERGROUND PLANNED PROTECTION SYSTEMS, INC. ("INDIANA 811") FOR UNDERGROUND UTILITY LOCATIONS. (1-800-382-5544).
- 6. BEFORE OPENING UP THE SITE, FIRST EVALUATE, MARK AND PROTECT IMPORTANT TREES AND ASSOCIATED ROOT ZONES, UNIQUE AREAS TO BE PRESERVED (I.E. WETLANDS), STREAMS, LAKES OR EXISTING
- VEGETATION SUITABLE FOR USE AS FILTER STRIPS (ESPECIALLY IN PERIMETER AREAS). 7. FIRST, STRIP AND STOCKPILE TOPSOIL ON-SITE.
- 8. BEGIN MASS EARTHWORK FOR PROPOSED IMPROVEMENTS.
- 9. REPAIR ANY SILT FENCING IF DAMAGED. IF SILT IS 1/3 HEIGHT OF FABRIC, REMOVE SILT AND REPLACE TO ORIGINAL CONDITION.
- 10. IMMEDIATELY AFTER GRADING, APPLY SURFACE STABILIZATION PRACTICES ON ALL GRADED AREAS, USING PERMANENT MEASURES IN ACCORDANCE WITH THE EROSION CONTROL PLAN. HOWEVER, IF WEATHER DELAYS PERMANENT STABILIZATION, TEMPORARY SEEDING AND/OR MULCHING MAY BE NECESSARY AS A PROVISIONAL MEASURE. ALSO STABILIZE (USING TEMPORARY SEEDING/MULCHING OR OTHER SUITABLE MEANS) ANY DISTURBED AREA WHERE ACTIVE CONSTRUCTION WILL NOT TAKE PLACE FOR 15 WORKING
- 11. AFTER CONSTRUCTION AND FINAL GRADING, PERMANENTLY STABILIZE ALL DISTURBED AREAS. ALSO REMOVE TEMPORARY RUNOFF CONTROL STRUCTURES, ANY UNSTABLE SEDIMENT AROUND THEM, AND STABILIZE THOSE AREAS WITH PERMANENT SEEDING AND EROSION CONTROL BLANKET IF NECESSARY.
- 12. MAINTAIN ALL EROSION AND SEDIMENT CONTROL PRACTICES UNTIL ALL DISTURBED AREAS ARE PERMANENTLY STABILIZED.

CONSULTANTS


₹ ৳ 집 ●●●●●


ST

SDS Checked By: Quality Assurance:


1" = 20' 2020/04/21

Project Number 990433-10705





SECTION A-A **BELOW GRADE SYSTEM**



INSTALLATION


- INSTALL AND LOCATE ACCORDING TO THE MANUFACTURER'S RECOMMENDATIONS.
- DESIGNED AND INSTALLED SYSTEMS
- UTILIZE AND FOLLOW THE DESIGN IN THE STORM WATER POLLUTION PREVENTION PLAN TO INSTALL THE SYSTEM. DEPENDENT UPON THE TYPE OF SYSTEM, EITHER EXCAVATE THE PIT OR INSTALL THE CONTAINMENT SYSTEM. A BASE SHALL BE CONSTRUCTED AND PREPARED THAT IS FREE OF ROCKS AND OTHER DEBRIS THAT MAY CAUSE
- TEARS OR PUNCTURES IN THE POLYETHYLENE LINING. • INSTALL THE POLYETHYLENE LINING. FOR EXCAVATED SYSTEMS, THE LINING SHOULD EXTEND OVER THE ENTIRE EXCAVATION. THE LINING FOR BERMED SYSTEMS SHOULD BE INSTALLED OVER THE POOLING AREA WITH ENOUGH
- MATERIAL TO EXTEND THE LINING OVER THE BERM OR CONTAINMENT SYSTEM. THE LINING SHOULD BE SECURED WITH PINS, STAPLES, OR OTHER FASTENERS. PLACE FLAGS, SAFETY FENCING, OR EQUIVALENT TO PROVIDE A BARRIER TO CONSTRUCTION EQUIPMENT AND
- OTHER TRAFFIC.
- PLACE A NON-COLLAPSING, NON-WATER HOLDING COVER OVER THE WASHOUT FACILITY PRIOR TO A PREDICTED RAINFALL EVENT TO PREVENT ACCUMULATION OF WATER AND POSSIBLE OVERFLOW OF THE SYSTEM (OPTIONAL).
- INSTALL SIGNAGE THAT IDENTIFIES CONCRETE WASHOUT AREAS. POST SIGNS DIRECTING CONTRACTORS AND SUPPLIERS TO DESIGNATED LOCATIONS.
- WHERE NECESSARY, PROVIDE STABLE INGRESS AND EGRESS OR ALTERNATIVE APPROACH PAD FOR CONCRETE

<u>MAINTENANCE</u>

- INSPECT DAILY AND AFTER EACH STORM EVENT.
- INSPECT THE INTEGRITY OF THE OVERALL STRUCTURE INCLUDING, WHERE APPLICABLE, THE CONTAINMENT SYSTEM. INSPECT THE SYSTEM FOR LEAKS, SPILLS, AND TRACKING OF SOIL BY EQUIPMENT.
- INSPECT THE POLYETHYLENE LINING FOR FAILURE, INCLUDING TEARS AND PUNCTURES. • ONCE CONCRETE WASTES HARDEN, REMOVE AND DISPOSE OF THE MATERIAL.
- EXCESS CONCRETE SHOULD BE REMOVED WHEN THE WASHOUT SYSTEM REACHES 50 PERCENT OF THE DESIGN CAPACITY. USE OF THE SYSTEM SHOULD BE DISCONTINUED UNTIL APPROPRIATE MEASURES CAN BE INITIATED TO CLEAN THE STRUCTURE. PREFABRICATED SYSTEMS SHOULD ALSO UTILIZE THIS CRITERION, UNLESS THE
- MANUFACTURER HAS ALTERNATE SPECIFICATIONS. • UPON REMOVAL OF THE SOLIDS, INSPECT THE STRUCTURE. REPAIR THE STRUCTURE AS NEEDED OR CONSTRUCT
- A NEW SYSTEM. • DISPOSE OF ALL CONCRETE IN A LEGAL MANNER. REUSE THE MATERIAL ON SITE, RECYCLE, OR HAUL THE MATERIAL TO AN APPROVED CONSTRUCTION/DEMOLITION LANDFILL SITE. RECYCLING OF MATERIAL IS ENCOURAGED. THE WASTE MATERIAL CAN BE USED FOR MULTIPLE APPLICATIONS INCLUDING BUT NOT LIMITED TO ROADBEDS AND
- BUILDING. THE AVAILABILITY FOR RECYCLING SHOULD BE CHECKED LOCALLY. • THE PLASTIC LINER SHOULD BE REPLACED AFTER EVERY CLEANING; THE REMOVAL OF MATERIAL WILL USUALLY DAMAGE THE LINING.
- THE CONCRETE WASHOUT SYSTEM SHOULD BE REPAIRED OR ENLARGED AS NECESSARY TO MAINTAIN CAPACITY FOR CONCRETE WASTE.
- . CONCRETE WASHOUT SYSTEMS ARE DESIGNED TO PROMOTE EVAPORATION. HOWEVER, IF THE LIQUIDS DO NOT EVAPORATE AND THE SYSTEM IS NEAR CAPACITY IT MAY BE NECESSARY TO VACUUM OR REMOVE THE LIQUIDS AND DISPOSE OF THEM IN AN ACCEPTABLE METHOD. DISPOSAL MAY BE ALLOWED AT THE LOCAL SANITARY SEWER AUTHORITY PROVIDED THEIR NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMITS ALLOW FOR ACCEPTANCE OF THIS MATERIAL. ANOTHER OPTION WOULD BE TO UTILIZE A SECONDARY CONTAINMENT SYSTEM OR BASIN FOR FURTHER DEWATERING
- PREFABRICATED UNITS ARE OFTEN PUMPED AND THE COMPANY SUPPLYING THE UNIT PROVIDES THIS SERVICE. · INSPECT CONSTRUCTION ACTIVITIES ON A REGULAR BASIS TO ENSURE SUPPLIERS, CONTRACTORS, AND OTHERS ARE UTILIZING DESIGNATED WASHOUT AREAS. IF CONCRETE WASTE IS BEING DISPOSED OF IMPROPERLY, IDENTIFY
- THE VIOLATORS AND TAKE APPROPRIATE ACTION. WHEN CONCRETE WASHOUT SYSTEMS ARE NO LONGER REQUIRED, THE CONCRETE WASHOUT SYSTEMS SHALL BE
- CLOSED. DISPOSE OF ALL HARDENED CONCRETE AND OTHER MATERIALS USED TO CONSTRUCT THE SYSTEM. HOLES, DEPRESSIONS AND OTHER LAND DISTURBANCES ASSOCIATED WITH THE SYSTEM SHOULD BE BACKFILLED, GRADED, AND STABILIZED.

CONCRETE WASHOUT

NOT TO SCALE



<u>INSTALLATION</u>

1. REMOVE THE GRATE FROM THE CATCH BASIN.

- 2. IF USING OPTION OIL ABSORBENTS, PLACE ABSORBENT PILLOW IN UNIT. 3. STAND THE GRATE ON END, MOVE THE TOP LIFTING STRAPS OUT OF THE WAY AND PLACE THE GRATE INTO THE DANDY SACK SO THAT THE GRATE IS BELOW THE TOP STRAPS AND ABOVE THE LOWER STRAPS.
- 4. HOLDING THE LIFTING DEVICES, INSERT THE GRATE INTO THE INLET. 5. MAKE SURE THE CYLINDRICAL PORTION IS UP AGAINST THE CURB OPENING TO PREVENT SILT AND DEBRIS FROM ENTERING THE INLET.


<u>MAINTENANCE</u>

• REMOVE ALL ACCUMULATED SEDIMENT AFTER EACH STORM EVENT. DISPOSE OF SEDIMENT IN AN AREA WHERE IT WILL NOT REENTER THE PAVED AREA OR STORM DRAINS. TO EMPTY UNIT, LIFT THE UNIT OUT OF THE INLET B' USING THE LIFTING STRAPS AND REMOVE THE GRATE. IF USING OPTIONAL

OIL ABSORBENTS, REPLACE ABSORBENT WHEN NEAR SATURATION. CONTACT: 708-867-8446 • WHEN CONTRIBUTING DRAINAGE AREA HAD BEEN STABILIZED, REMOVE INLET

INSERT (BAG) CURB INLET PROTECTION WITH CURB FILTER

NOT TO SCALE




<u>MAINTENANCE</u>

• INSPECT AT LEAST ONCE EVERY SEVEN CALENDAR DAYS.

• REPAIR PERIMETER BARRIERS IF DAMAGED. • INSPECT FOR DAMAGE FROM CONSTRUCTION EQUIPMENT, ETC. REPAIR WOUNDS SIMPLY BY REMOVING DAMAGED BARK AND WOOD TISSUE. DO NOT USE TREE PAINT. • CABLE AND BRACE ANY TRUNK SPLITS, WEAK FORKS, AND LARGE LIMBS.

TREE PRESERVATION FENCING (SINGLE)

NOT TO SCALE



1. DIG AN EIGHT-INCH DEEP, FOUR-INCH WIDE TRENCH AROUND THE PERIMETER OF THE INLET. 2. IF USING PRE-ASSEMBLED GEOTEXTILE FABRIC AND POSTS, DRIVE THE POSTS INTO THE SOIL, TIGHTLY STRETCHING THE GEOTEXTILE FABRIC BETWEEN POSTS AS EACH IS DRIVEN. (POSTS MUST BE PLACED ON THE INLET SIDE OF THE ANCHOR TRENCH WITH THE GEOTEXTILE FABRIC ON THE SIDE OF THE TRENCH FARTHEST FROM

NOTE: IF ASSEMBLING THE GEOTEXTILE FABRIC AND POSTS ON-SITE, DRIVE THE POSTS INTO THE SOIL AND THEN SECURE THE GEOTEXTILE FABRIC TO THE POSTS BY PLACING A PIECE OF LATHE OVER THE FABRIC AND FASTENING IT TO THE POST (STRETCHING THE FABRIC BETWEEN POSTS AS IT IS FASTENED).

3. USE THE WRAP JOIN METHOD WHEN JOINING POSTS

- 4. PLACE THE BOTTOM 12 INCHES OF GEOTEXTILE FABRIC INTO THE EIGHT-INCH DEEP TRENCH, LAYING THE REMAINING FOUR INCHES IN THE BOTTOM OF THE TRENCH AND EXTENDING AWAY FROM THE INLET.
- 5. BACKFILL THE TRENCH WITH SOIL MATERIAL AND COMPACT IT IN PLACE. 6. BRACE THE POSTS BY NAILING BRACES INTO EACH CORNER POST OR UTILIZE RIGID PANELS TO SUPPORT FABRIC.


<u>MAINTENANCE</u>

 INSPECT DAILY. • INSPECT GEOTEXTILE FABRIC AND MAKE NEEDED REPAIRS IMMEDIATELY.

- REMOVE SEDIMENT FROM POOL AREA TO PROVIDE STORAGE FOR THE NEXT STORM EVENT. AVOID DAMAGING OR
- UNDERCUTTING FABRIC DURING SEDIMENT REMOVAL. • WHEN CONTRIBUTING DRAINAGE AREA HAS BEEN STABILIZED, REMOVE SEDIMENT, PROPERLY DISPOSE OF ALL CONSTRUCTION MATERIAL, GRADE AREA TO THE ELEVATION OF THE STORM DRAIN INLET TOP, THEN STABILIZE

GEOTEXTILE FABRIC YARD INLET DROP PROTECTION

NOT TO SCALE



<u>INSTALLATION</u>

- 1. LAY OUT THE LOCATION OF THE FENCE SO THAT IT IS PARALLEL TO THE CONTOUR OF THE SLOPE AND AT LEAST 10 FEET BEYOND THE TOE OF THE SLOPE TO PROVIDE A SEDIMENT STORAGE AREA. TURN THE ENDS OF THE FENCE UP SLOPE SUCH THAT THE POINT OF CONTACT BETWEEN THE GROUND AND THE BOTTOM OF THE FENCE END TERMINATES AT A HIGHER ELEVATION THAN THE TOP OF THE FENCE AT ITS LOWEST POINT.
- 2. EXCAVATE AN EIGHT-INCH DEEP BY FOUR-INCH WIDE TRENCH ALONG THE ENTIRE LENGTH OF THE FENCE LINE. INSTALLATION BY PLOWING IS ALSO ACCEPTABLE. 3. INSTALL THE SILT FENCE WITH THE FILTER FABRIC LOCATED ON THE UP-SLOPE SIDE OF THE EXCAVATED
- TRENCH AND THE SUPPORT POSTS ON THE DOWN-SLOPE SIDE OF THE TRENCH. 4. DRIVE THE SUPPORT POSTS AT LEAST 18 INCHES INTO THE GROUND, TIGHTLY STRETCHING THE FABRIC BETWEEN THE POSTS AS EACH IS DRIVEN INTO THE SOIL. A MINIMUM OF 12 INCHES OF THE FILTER FABRIC
- SHOULD EXTEND INTO THE TRENCH.
- 5. LAY THE LOWER FOUR INCHES OF FILTER FABRIC ON THE BOTTOM OF THE TRENCH AND EXTEND IT TOWARD THE UP-SLOPE SIDE OF THE TRENCH.
- 6. BACKFILL THE TRENCH WITH SOIL MATERIAL AND COMPACT IT IN PLACE. NOTE: IF THE SILT FENCE IS BEING CONSTRUCTED ON-SITE, ATTACH THE FILTER FABRIC TO THE SUPPORT POSTS AND ATTACH WOODEN LATHE TO SECURE THE FABRIC TO THE POSTS. ALLOW FOR AT LEAST 12 INCHES OF FABRIC BELOW GROUND LEVEL. COMPLETE THE SILT FENCE INSTALLATION, FOLLOWING STEPS 1 THROUGH 6

<u>MAINTENANCE</u>

- . INSPECT WITHIN 24 HOURS OF A RAIN EVENT AND AT LEAST ONCE EVERY SEVEN CALENDAR DAYS. • IF FENCE FABRIC TEARS, STARTS TO DECOMPOSE, OR IN ANY WAY BECOMES INEFFECTIVE, REPLACE THE AFFECTED PORTION IMMEDIATELY. NOTE; ALL REPAIRS SHOULD MEET SPECIFICATIONS AS OUTLINED WITHIN THIS
- REMOVE DEPOSITED SEDIMENT WHEN IT IS CAUSING THE FILTER FABRIC TO BULGE OR WHEN IT REACHES
- ONE-HALF THE HEIGHT OF THE FENCE AT ITS LOWEST POINT. WHEN CONTRIBUTING DRAINAGE AREA HAS BEEN STABILIZED, REMOVE THE FENCE AND SEDIMENT DEPOSITS, GRADE THE SITE TO BLEND WITH THE SURROUNDING

SILT FENCE BARRIER INSTALLATION

NOT TO SCALE

CONSULTANTS

•••••




TER POLLUI

Alc. Fut

Drown By: SDS Checked By: Quality Assurance:

> 1'' = 20' 2020/04/21 Project Number



END SECTION STORM SEWER INLETS TAPPING SLEEVE & VALVE FIRE DEPARTMENT CONNECTION POST INDICATOR VALVE ELECTRIC METER CABLE RISER PEDESTAL

- 3. SITE UTILITY CONTRACTOR TO VERIFY BUILDING CONNECTION LOCATIONS AND ELEVATIONS WITH MEP AND

- 6. WATER AND SEWER CROSSINGS AND SEPARATIONS SHALL BE IN ACCORDANCE WITH "TEN STATE

- 10. INVERT ELEVATION OF SUB-SURFACE DRAIN (SSD) AT STRUCTURE TO BE THREE (3) FEET BELOW RIM
- 13. SEE STRUCTURE DATA TABLE DETAIL ON SHEET C60X FOR STRUCTURE AND CASTING TYPE AND SIZE.
- 15. ANY DISCREPANCIES OR CONFLICTS WHICH BECOME APPARENT BEFORE OR DURING CONSTRUCTION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER OF RECORD IMMEDIATELY SO THAT CLARIFICATION OR
- (3) EXISTING STORM CASTING TO REMAIN IN PLACE AND BE UNDISTURBED DURING CONSTRUCTION

<u>CONSULTANTS</u>


₹ ৳ 집 ●●●●●



SDS JCZ Quality Assurance:

1'' = 20'

2020/04/21 Project Number



880 L -0+25

0+00

0+50

PROFILE - STR 701 - STR 705

HOR SCALE = 1"=20"

VERT. SCALE = 1"=3"

1+00

880 L -0+25

0+00

880 L -0+25

0+00

0+50

PROFILE - STR 701 - STR 703

HOR SCALE = 1"=20"

VERT. SCALE = 1"=3"

1 + 00

0+50

PROFILE - EX. STR 700 - STR 701

HOR SCALE = 1"=20"

VERT. SCALE = 1"=3"

<u>CONSULTANTS</u>

RIORITY WAY SOUTH DRIVE
SUITE 200
NAPOLIS, INDIANA 46240
hone (317) 844-6777
-Mail cripe@cripe.biz

ARCHITECTURE + INTERIORS
CIVIL ENGINEERING
SURVEY + 3D LASER SCANNING
ENERGY + FACILITIES
ENERGY + FACILITIES
ENERGY + FACILITIES
ENERGY PACILITIES
ENERGY PACILITIE

SUITE SUITE (NDIANAPOLIS, IF Phone (317) E-Mail cripe (4 CYLL ENGINE CYLL ENGI

CLIPD B

MILTON COUNTY PARKS

NSHIP CHILDREN'S PAVILION AT COXHALL

BY:

C.

TEAN

C.

TEAN

THE GISTER

THE G

CERTIFIED BY:

C.

PE 19900434

STATE OF

NOIANA

STATE OF

NOIANA

STATE OF

NOIANA

STATE OF

NOIANA

STATE OF

Drown By:

SDS

Checked By:


JCZ

Ouality Assurance:

DJP

Scole:

Scale: 1" = 20'



GENERAL PLANTING NOTES

- PLANT MATERIAL SHALL BE INSTALLED AND MAINTAINED BY A QUALIFIED AND EXPERIENCED LANDSCAPE CONTRACTOR.
- LOCATE AND VERIFY ALL PUBLIC AND PRIVATE UTILITIES PRIOR TO STARTING LANDSCAPE WORK.
- STAKE AND CONFIRM ALL DIMENSIONS, GRADES, AND PLANT LAYOUT PRIOR TO STARTING WORK. REPORT ANY
- DISCREPANCIES TO LANDSCAPE ARCHITECT IMMEDIATELY. SEED ALL AREAS DISTURBED BY CONTRACTOR'S OPERATIONS,
- INCLUDING AREAS BEYOND.
- PLANTING BEDS SHALL RECEIVE SPADE EDGE UNLESS OTHERWISE NOTED.
- CONTRACTOR SHALL PROVIDE PLANT MATERIAL IN QUANTITIES AND SPECIES SHOWN ON PLANS. SUBSTITUTIONS SHALL NOT BE ALLOWED UNLESS SUBMITTED IN WRITING AT LEAST 10 DAYS PRIOR TO BID DATE AND APPROVED VIA ADDENDUM BY LANDSCAPE ARCHITECT.
- AMEND OR INSTALL TOPSOIL MEETING ASTM D5268 STANDARDS, TOPSOIL SHALL BE FREE OF DELETERIOUS MATERIALS OR EXTRANEOUS MATERIALS LARGER THAN 1". VERIFY DEPTH AND QUALITY OF TOPSOIL PRIOR TO PLANT INSTALLATION. LAWN AREAS SHALL HAVE A MIN. OF 4" TOPSOIL, AND PLANTING BEDS A MIN. OF 12". TOPSOIL SHALL BE STOCKPILED AND REUSED ON SITE. WHERE QUANTITIES ARE INSUFFICIENT, TOPSOIL MAY BE IMPORTED FROM OFF SITE. DO NOT OBTAIN FROM BOGS, MARSHES, WETLANDS, OR AGRICULTURAL LAND. APPLY INORGANIC AMENDMENTS, ORGANIC AMENDMENTS, AND FERTILIZERS AS NEEDED FOR LONG TERM PLANT HEALTH.
- ROOT BALL SHALL MEET OR EXCEED SIZES SET FORTH IN CURRENT AMERICAN STANDARDS FOR NURSERY STOCK.
- AROUND ALL TREES IN LAWN AREAS.

PROVIDE 3" SHREDDED HARDWOOD MULCH IN 6` DIAMETER

- PROVIDE PRE-EMERGENT HERBICIDE ON PLANTING BEDS AT RATES PER MANUFACTURER'S DIRECTIONS.
- TREES SHALL NOT BE STAKED EXCEPT WITH APPROVAL FROM LANDSCAPE ARCHITECT FOR ACCOMMODATION OF ENVIRONMENTAL CONDITIONS.
- INSTALL ALL PLANT MATERIAL IN ACCORDANCE WITH LOCAL CODES AND ORDINANCES. CONTRACTOR SHALL OBTAIN ALL REQUIRED PERMITS AS REQUIRED BY LOCAL JURISDICTIONS.
- PLANT MATERIAL AND WORKMANSHIP SHALL BE WARRANTED FOR A PERIOD OF 1 YEAR FROM SUBSTANTIAL COMPLETION. REPLACE ALL PLANTS MORE THAN 1/4 DEAD AS SOON AS WEATHER CONDITIONS ALLOW THROUGHOUT WARRANTEE PERIOD.
- QUANTITIES SHOWN IN PLANT SCHEDULE ARE FOR LANDSCAPE ARCHITECT'S PURPOSES AND FOR LOCAL REGULATORY REVIEW. CONTRACTOR IS RESPONSIBLE TO PROVIDE PLANTS IN QUANTITIES AND SPACING AS DEPICTED ON PLANTING PLANS, IF DISCREPANCIES EXIST QUANTITIES SHOWN ON PLANS SHALL DICTATE.

IRRIGATION NOTES

- A. IRRIGATION SHALL BE PROVIDED AS DESIGN BUILD STAND ALONE SYSTEM. MATERIALS SHALL MATCH EXISTING WITHIN COXHALL GARDEN. CONTROLLER SHALL BE IN ADJACENT BATHROOM OR WITHIN NEW PAVILLION STRUCTURE. COORDINATE FINAL LOCATION ON SITE WITH OWNER.
- B. PROVIDE IRRIGATION WITHIN LIMITS SHOWN.
- C. UTILIZE ROTORS/SPRAY FOR LAWN AREAS.
- D. UTILIZE LOW FLOW TECHNIQUES WITHIN ALL PLANTING BEDS.
- IRRIGATION CONTRACTOR SHALL PROVIDE HEAD LAYOUT FOR ALL AREAS TO BE IRRIGATED. VERIFY WATER PRESSURE TO ENSURE ZONES WILL RECEIVE ADEQUATE PRESSURE FOR ALL HEADS AND ROTORS.
- F. IT IS THE RESPONSIBILITY OF THE IRRIGATION CONTRACTOR TO BE FAMILIAR WITH ALL GRADE DIFFERENCES, LOCATIONS OF WALLS, STRUCTURES AND UTILITIES AND MAKE THE NECESSARY ADJUSTMENTS TO ACCOMMODATE THE IRRIGATION SYSTEM AS DESIGNED.
- G. THE IRRIGATION CONTRACTOR SHALL VERIFY WATER PRESSURE PRIOR TO DESIGN AND CONSTRUCTION. REPORT DIFFERENCES BETWEEN REQUIREMENTS AND ACTUAL READINGS TO THE OWNER'S AUTHORIZED REPRESENTATIVE. A BOOSTER PUMP MAY BE NECESSARY IF THE REQUIRED PRESSURE IS NOT AVAILABLE. ADDITIONAL WORK SHALL BE COORDINATED WITH CONSTRUCTION MANAGER. VERIFY EXACT POINT OF CONNECTION LOCATION IN THE FIELD WITH THE OWNER'S REPRESENTATIVE. THE FLOW DEMAND FOR INDIVIDUAL MAINLINES SHALL NOT EXCEED THE FOLLOWING GUIDELINES: 1.25" CLASS 160=18-28GPM.
- H. UTILIZE EXISTING POWER SOURCE AT THE CONTROLLER LOCATION. THE IRRIGATION CONTRACTOR SHALL MAKE THE FINAL CONNECTION FROM THE ELECTRICAL SOURCE TO THE CONTROLLER.
- I. A RAIN SENSOR SHALL BE INSTALLED IN THE VICINITY OF THE CONTROLLER. COORDINATE MOUNTING LOCATION WITH THE
- J. INSTALL ALL BACKFLOW PREVENTION DEVICES AND ALL PIPING BETWEEN THE POINT OF CONNECTION AND THE BACKFLOW PREVENTER AS PER LOCAL CODES.
- AUTOMATIC CONTROLLER SHALL BE APPROVED BY THE OWNERS REPRESENTATIVE PER LOCAL CODES. A QUICK COUPLING VALVE SHALL BE LOCATED AT THE IRRIGATION WATER SUPPLY POINT OF CONNECTION TO PROVIDE
- FOR A POINT OF INJECTION OF COMPRESSED AIR TO PURGE THE SYSTEM OF RETAINED WATER FOR WINTERIZATION. M. ALL PIPE AND COMMUNICATION WIRE UNDER HARD SURFACES
- WHENEVER POSSIBLE WITH THE MAINLINE.

SHALL BE PLACED IN SEPARATE SLEEVING. ALL WIRE SHALL RUN

- N. ALL LATERAL ZONES SHALL BE CONNECTED TO THE MAINLINE WITH PVC PIPE AND SIZED AS FOLLOWS: 1" CLASS 200=0-30GPM
- O. ALL SPRINKLER HEADS SHALL BE SET PERPENDICULAR AND FLUSH TO FINISH GRADE AND WITH A CLEARANCE OF 2" (MIN.) FROM THE EDGE OF ANY HARDSCAPE UNLESS OTHERWISE
- P. CHECK VALVES SHALL BE INSTALLED ON ALL IRRIGATION HEADS IN AREAS WHERE FINISH GRADE EXCEEDS 4:1, WHERE POST VALVE SHUTOFF DRAINING OF THE IRRIGATION HEAD OCCURS OR AS DIRECTED BY THE OWNER'S REPRESENTATIVE.
- Q. ALL SPRINKLER HEADS AND VALVES SHALL BE FLUSHED AND ADJUSTED FOR OPTIMUM COVERAGE WITH MINIMUM OVERSPRAY ON HARDSCAPES OR BUILDINGS.
- R. PROVIDE PRESSURE COMPENSATING SCREENS AND/OR NOZZLES TO REDUCE OR ELIMINATE OVERSPRAY INTO WALKS, STREETS, OR OTHER AREAS DIRECTED BY THE OWNER'S AUTHORIZED REPRESENTATIVE.
- S. ALL IRRIGATION EQUIPMENT SHALL BE INSTALLED AS PER MANUFACTURER'S RECOMMENDATIONS AND SPECIFICATIONS.

5' 10'

SCALE: 1" = 10'-0"

00000

CONSULTANTS


IAMILTON

LH

ΜT

Approver 1" = 10'-0"

2020/04/21



CONSULTANTS

₹ E T 00000

PLANTING DETAILS
HAMILTON COUNTY PARKS

LA20000264

STATE OF

LH

MT Approver

1'' = 10'-0''

L200 2020/04/21




FOUNDATION PLAN
HAMILTON COUNTY PARKS

860325 STATE OF


KLS ACV

CRM 1/8" = 1'-0" 2020/04/21

990433-10705



13' - 4"



13' - 4"

FOUNDATION PLAN NOTES: 1. ELEVATIONS ±, ARE FROM NOMINAL FIRST FLOOR ELEV +0'-0", SEE CIVIL DRAWINGS. 2. SEE S401 FOR GENERAL NOTES AND S402 FOR SCHEDULES. 3. SEE ARCHITECTURAL DRAWINGS FOR ALL DIMENSIONS NOT SHOWN. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION AND NOTIFY ARCHITECT/ENGINEER OF ANY DISCREPANCIES IMMEDIATELY.

4. TOP OF SLAB (T/SLAB) +100'-0", UNO. 5. TOP OF FOOTING (T/F) +98"-6", UNO. 6. TOP OF PIERS (T/P) +100"-0", UNO. 7. TOP OF WALL FOOTING (T/WF) +(100'-0") 8. ALTERNATE FOR BIDDING INCLUDES BRICK VENEER COLUMN WRAPS AT SHELTER STRUCTURE, SEE 05/S403. 9. ALL STRUCTURAL STEEL AND PERGOLA STEEL PROVIDED BY OTHERS, (TYP). 10. ALL EXTERIOR EXPOSED STEEL IS REQUIRED TO BE GALVANIZED FOR CORROSION PROTECTION.

ACV CRM

2020/04/21

990433-10705

KLS 1/8" = 1'-0"



ALTERNATE FOUNDATION PLAN

MW8 WF28

- FOUNDATION PLAN NOTES:
- 3. SEE ARCHITECTURAL DRAWINGS FOR ALL DIMENSIONS NOT SHOWN. CONTRACTOR SHALL VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION AND NOTIFY
- ARCHITECT/ENGINEER OF ANY DISCREPANCIES IMMEDIATELY. 4. TOP OF FOOTING (T/F) +97'-10", UNO. 5. TOP OF PIERS (T/P) +99'-4", UNO. 6. ALTERNATE FOR BIDDING INCLUDES BRICK VENEER COLUMN WRAPS AT SHELTER STRUCTURE, SEE 05/S403.
 7. ALL STRUCTURAL STEEL AND PERGOLA STEEL PROVIDED BY OTHERS, (TYP).

ROOF DESIGN LOADS Spread Allowable Bearing Pressure, qa: 2000 psf 2000 psf Minimum Foundation Bearing Depth: 36 in

SLAB ON GRADE Compacted Fill Thickness: 6 in 95% Modified Proctor D-1557 Compaction Specification: SNOW DESIGN CRITERIA

Ground Snow Load, Pg: 20 psf Flat Roof Snow Load, Pf 15 psf Importance Factor, Is: 1.0 0.9 Fully Exposure Factor, Ce: 1.2 Thermal Factor, Ct: Unheated Cold Slope Factor, Cs: 1.0

WIND DESIGN CRITERIA 115 mph Ultimate Wind Speed, Vult: Design Wind Speed, VASD: 90 mph Enclosure Class: Enclosed Internal Pressure Coefficient, GCpi: 0.18 SEISMIC DESIGN CRITERIA

GENERAL NOTES

DESIGN TABLE

Steel Standard:

Model Building Code:

Local Building Code:

Model Code Standard:

Steel Seismic Standard

Concrete Standard:

Masonry Standard:

Wood Standard:

Risk Category:

Main Shelter

Pergola

Importance Factor, le: Mapped Spectral Response, SS: 0.150 Mapped Spectral Response, S1: Site Class: Design Spectral Response, SDS: 0.160 Design Spectral Response, SD1: Seismic Design Category, SDC: Overstrength Factor, Ω : Seismic Response Coefficient, CS: 0.053 Response Modification Coeff., R: 5.3% W Unfactored Design Base Shear, V:

Analysis Procedure: Basic Seismic-Force-Resisting System: A. Steel Systems not Specifically Detailed for Seismic Resistance 1. Steel Systems, R=3

Reactions and forces indicated are unfactored, Allowable Strength Design (ASD) loads. If Drawings and specifications are in conflict, the most stringent restrictions and requirements shall govern. Contractor shall bring all

discrepancies to the attention of the engineer immediately. Verify all existing conditions prior to any construction or fabrication. If different than shown, notify engineer/architect immediately for modification of drawings. All contractors are required to coordinate their work with all disciplines to avoid conflicts. The architectural, mechanical, electrical and plumbing aspects are not in the scope of these drawings. Therefore, all required materials and work may not be indicated. It is the

structural drawings. The respective contractor shall verify their work with all other disciplines.

The contract documents represent the structure only. They do not indicate the method of construction. The contractor shall provide all measures necessary to protect the structure during construction. Such measures shall include, but not limited to, bracing, shoring, underpinning, etc. the Engineer of Record is not responsible for the contractor's means, methods, techniques, sequences or safety procedures during construction.

Notes and details shall take precedence over general structural notes. Where no details or sections are shown, construction shall

conform to similar work on the project. Typical sections and details may not be cut on the plans, but apply unless noted otherwise. Vertical: None

Horizontal:

SF1. Soil to be stripped, compacted and tested in accordance with the recommendations of the soils engineer and

graded mixture of natural or crushed gravel, crushed stone, and natural or crushed sand; ASTM D 2940; with at least 90 percent passing a 1-1/2-inch sieve and not more than 12 percent passing a No. 200 sieve. Slabs shall be placed on compacted, free-draining, frost-free drainage course. Drainage Course: Narrowly graded mixture of washed crushed stone, or crushed or uncrushed gravel; ASTM D 448; coarse-aggregate grading Size 57; with 100 percent passing a 1-1/2-inch sieve and 0 to 5 percent passing a No. 8 sieve. All fill

recommendations. the entire scope of undercutting, fill or bad soil removal that may be required to attain the design soil bearing pressures. It is the responsibility of the contractor to obtain a soils investigation report, before bidding, to assess the extent of excavation and compaction that may be required to meet the design criteria. The contractor shall retain the services of a soils engineer to monitor all backfilling operations and to inspect footing bearing material. A report certified by the soils engineer shall be furnished to the architect/engineer verifying that all foundations were placed on a material capable of sustaining the design bearing pressures.

If dewatering is required, sumps shall not be placed within the foundation excavation. Maintain a maximum slope between adjacent footing bearing elevations of 2 horizontal to 1 vertical. Maintain a

2 horizontal to 1 vertical slope next to existing foundations to avoid undermining foundations. No horizontal joints are permitted in any foundation. Vertical joints are permitted only in wall footings.

Shallow foundations may be earth-formed where the excavation permits. If earth-forming is used, add 2" to the width and length of all foundations.

contractor's responsibility to coordinate these drawings with all other construction documents. Refer to architectural drawings for all

dimensions not shown on these drawings. Locations, sizes and numbers of all openings may not be completely indicated in the

Provisions for future expansion:

020000 SHALLOW FOUNDATION AND SLAB ON GRADE NOTES

SF2. Footings shall be placed on firm, undisturbed soil or on engineered fill. Engineered Fill: Naturally or artificially

shall be compacted to a minimum dry density of 95% of the modified Proctor maximum dry density (ASTM-D1557), placed in 6" to 8" lifts. Pea gravel may not be used as fill. Utility trenches and excavations under the foundations or slabs shall meet the same requirements. See soils investigation report for further

SF4. Undercutting of the soil for foundation and/or slab placement may be required. These drawings do not indicate

The bottom of all foundations shall be a minimum of local frost depth below final grade.

ப் •••••

COUNTY HAMILTON

860325 STATE OF

> KLS ACV

3/4" = 1'-0"

CRM

2020/04/21 990433-10705



033000 CAST IN PLACE CONCRETE NOTES (Foundations, Slabs, & Walls) RC1. All concrete shall have the following 28 day compressive strengths:

STRENGTH LOCATION 3000 psi-0% AE All foundations and footings 4000 psi-6% AE Exterior slabs, piers, walls, columns, grade beams and concrete exposed to freezing 4000 psi-0% AE Interior slabs, fill for metal deck and all other interior concrete

RC2. All reinforcing shall conform to the following concrete cover: COVER Footings: All surfaces; All concrete cast against soil

Foundations & Footings: All surfaces; Exterior Slabs: Bottom; Grade Beams & Trench

Interior beams, columns & walls: All surfaces; All concrete not exposed to weather or in Interior slabs & Walls

Exterior Walls, All Piers & All Pilasters: All surfaces; Exterior Slabs: Top; All exterior concrete Welded Wire Fabric (WWF) for slabs and fill for metal deck shall be placed in the upper-third of the slab or fill. See

All reinforcing steel shall be detailed, supplied and placed in accordance with ACI 315, ACI 318 and CRSI MSP-1. RC5. All reinforcing steel shall be shop fabricated and, where applicable, shall be wired together and conform to ASTM A-615, Grade 60. Chamfer edges of exposed concrete 3/4", unless noted otherwise.

Contractor shall make four, 6"x12" test cylinders for each 50 cubic yards of concrete poured for each days operation. Break 1 at 7 days, 2 at 28 days and retain spare. All welded wire fabric shall conform to ASTM A185, Fy(min) of 65 ksi. All welded wire fabric laps shall be 8". All finished concrete, concrete formwork and falsework shall be in accordance with ACI 301. Contractor is solely responsible for the design and construction of all formwork, falsework and shoring.

Provide sleeves for all openings in grade beams or walls to totally separate pipe from concrete Foundations may be earth-formed where the excavation permits. If earth-forming is used, add 2" to the width, length & thickness of all foundations.

Plastic Vapor Retarder: ASTM E 1745, Class A, not less than 10 mils (0.25 mm) thick, see specifications. Include manufacturer's recommended adhesive or pressure-sensitive joint tape. Fiber Reinforcement, if indicated on drawings, shall be 100% virgin polypropylene in collated, fibrillated form,

complying with ASTM C 1116, minimum length of 3/4". Minimum dosage = 1.5 pounds per cubic yard. Adhesive Anchors and Adhesives Used for Reinforcing Anchorage: The adhesive anchor system used for post-installed anchorage to concrete shall conform to the

requirements of the most recently published ACI 355.4. Adhesive anchors indicated are the Basis-of-Design. Approved equal meeting ACI 355.4 is permitted. Bulk-mixed adhesives are not permitted.

Anchors shall be supplied as an entire system with manufacturer's recommendations adhered to. Adhesive anchors shall be installed by qualified personnel trained to install adhesive anchors. Installation of adhesive anchors horizontally or upwardly inclined shall be performed by personnel certified by the ACI/CRSI Adhesive Anchor Installer Certification program.

Minimum 28 day compressive strength of concrete masonry units shall be 2800 p.s.i. based on net area

All mortar shall be Type S. No admixtures may used unless approved by architect/engineer. Mortar shall

of the unit. Specified design compressive strength of masonry shall be f'm = 2000 p.s.i. All units for

Course grout shall be used were grouting is required. Slump shall be 8" +/- 1". Minimum grout

All reinforcing shall be ASTM A615 Grade 60 (Fy=60 ksi). Lap all reinforcing a minimum of 48 bar

See architectural and specifications for all control joint locations. Reinforcing in bond beams shall be

Provide ladder type horizontal joint reinforcement at 16" o.c. Side rods and cross rods shall be #9 wire,

Fill cores of block solid with grout two full courses below the bearing of all beams or lintels supported on

All attachments to block shall be made with Hilti HLC 1/2" diameter x 3" sleeve anchors, unless noted

All interior, non-load bearing masonry walls over 12'-0" high, shall be supported on thickened slab as per

typical detail. Wall vertical reinforcing shall be #5 @ 48" OC full height. Unless noted otherwise.

exterior walls, load-bearing walls and shear walls shall be normal weight block.

Adhesive anchors installed in horizontal or upwardly inclined orientations shall be continuously inspected during installation by an inspector specially approved for that purpose. Bonding agent for bonding fresh concrete to hardened concrete: ASTM C 1059/C 1059M, Type II,

nonredispersible, acrylic emulsion or styrene butadiene.

042000 MASONRY AND REINFORCED MASONRY NOTES

not be used for grouting cores or filling bond beams.

Provide "L" bars at all bond beam corners as required.

All masonry units below grade to be grouted solid.

Center vertical reinforcing in block cores, unless noted otherwise.

galvanized, see specifications. Cut joint reinforcement at control joints.

otherwise. Anchors shall be installed per manufacturer's recommendations.

See typical schedules for masonry and steel lintels not indicated on plans.

All cores with reinforcing steel shall be grouted solid, full height of wall.

All block shall be laid in a running bond pattern.

compressive strength shall be 3000 p.s.i.

discontinuous at control ioints

Provide ties to all structural steel.

M13.

MASONRY WALL SCHEDULE (v3) **Top of Wall Bond Vertical Wall Reinforcing** Beam Reinforcing Horiz Reinf Reinforcing Dowel Reinforcing Mark | Thickness | Size | Spa | Location Size Spa Remarks Size Spa Size No. of 7 5/8" #5 4' - 0" Center #5 4' - 0" Ladder 1' - 4" #5 4' - 0" Ladder 1' - 4"

COLUMN FOOTING SCHEDULE (v2 simple)

Length

Ties

Spa

1' - 0"

Reinf | Control Jt | Vapor | Sub-Base

13' - 0" Plastic

| Retarder |

Spa

4' - 0"

Short Direction

Size

#6

PIER SCHEDULE (v3)

Size

SLAB ON GRADE SCHEDULE (v2)

| Clearance |

No

Vert Reinf

No

Size

Control Jt

Depth

Bottom Reinforcing

No

Tie Type

Long Direction

Size

Remarks

Depth

Remarks

Length

Remarks

MW10 9 5/8" #5 4' - 0" Center Masonry Wall Schedule Notes" 1. Provide 2" cover from outside face for bars in each face. 2. Grout all cores with rebar solid, unless solid grouted wall is shown. 3. Provide ladder type horizontal reinforcement at 16" o.c., unless noted otherwise. Side and cross rods shall be #9 wire, galvanized, see

4. Provide bond beam with (2) #5 cont. at top of wall, unless noted otherwise.

specifications. Cut joint reinforcement at control joints.

See schedule for additional bond beams.

Ftg Dimensions

1. Reinforcing clearance at bottom and sides of footings = 3"

2. Space first tie 2" from top of footing, last tie 2" from top of pier.

3. Provide (3) ties in top of pier, spacing = 2 1/2" on center.

5. Provide CRSI typical bar bend T9 additional ties for all piers

6. Provide 90° Hook for all ties per CRSI detailing standards.

Mark | Thickness | Reinforcing

SOG04P 4" 6x6-W1.4xW1.4 WWF

2. Use concrete brick of CRSI Class 3, CHCP wire bar supports @ 36".

Lengt

Mark | Width | h | Thickness |

F459 4' - 6" 9' - 0" 1' - 6"

Pier Size

Mark | Width |Length|

P24 2' - 0" 2' - 0"

1. Provide 2 inch concrete cover over ties.

4. Provide CRSI typical bar bend T5 for all ties.

with more than four vertical bars.

Slab on Grade Schedule Notes:

1. Reinforcing clearance is from the top of slab.

Pier Schedule Notes:

Column Footing Schedule Notes:

		WA	LL FOOTIN	G SCHEDULE	E (v2 simple)	
	Dim						
			Longitud	linal Reinf	Transve	rse Reinf	
Mark	Width	Thickness	No	Size	Size	Spa	Remarks
WF28	2' - 4"	1' - 6"	5	#5	NA	0"	
							1

WF56 4'-8" 1'-6" 10 #5 NA 0" Wall Footing Schedule Notes: 1. Reinforcing clearance at bottom and sides of footings = 3"

2. Use concrete brick of CRSI Class 3, CHCP wire bar supports @ 36".

ABBREVIATIONS LIST ANCHOR RODS

ADDITIONAL

ADHESIVE

ADJACENT

AGGR AGGREGATE

ALUM ALUMINUM

STRUCTURAL STEEL

AIR HANDLING UNIT

ABOVE FINISHED FLOOR

AMERICAN INSTITUTE OF

STEEL CONSTRUCTION

AMERICAN IRON AND

STEEL INSTITUTE

ALTERNATE

APPROX APPROXIMATE

ARCH'L ARCHITECTURAL

ANGLE

BOARD

BLOCK

BELOW

BEAM

BRDG BRIDGING

BTWN BETWEEN

BOTTOM

BEARING

BOTH SIDES

BASEMENT

CAMBER

CANTILEVER

CENTERLINE

CLEAR

COLUMN

COORD COORDINATE

COMP COMPACTED

CONC CONCRETE

CONN CONNECTION

CONT CONTINUOUS

CONTR CONTRACTOR

DIAMETER

DIAGONAL

DIMENSION

DEAD LOAD

DITTO

DOWN

DETAIL

DRAWING

EACH END

EACH FACE

ENGINEER

ELEVATION

EDGE OF SLAB

ELECT ELECTRICAL

EQUIV EQUIVALENT

EXIST EXISTING

EOD EDGE OF DECK

EQUAL

EACH SIDE

EACH WAY

EXPANSION

FLOOR DRAIN

FOUNDATION

EXTERIOR

FACE OF

FINISH

FLOOR

FLANGE

FARSIDE

FOOTING

GALVANIZED

GRADE BEAM

HOLLOW CORE HOLD DOWN

GENERAL CONTRACTOR

GAUGE

GLULAM

GRADE

HEIGHT

HIGH

HOOK

HIGH POINT

HEADED STUD

INSIDE DIAMETER

INSIDE FACE INFORMATION

INTERIOR INVERT

KNOCK OUT

LIVE LOAD

LLH LONG LEG HORIZONTAL

LONG SLOTTED HOLES

LAMINATED VENEER LUMBER

LLV LONG LEG VERTICAL

POUND LEDGE

LONG

LONG LONGITUDINAL LP LOW POINT

MASONRY

MATERIAL

MAXIMUM

MINIMUM

MECH MECHANICAL MEZZ MEZZANINE

MOM MOMENT

MBM METAL BUILDING MFR MCJ MASONRY CONTROL JT

MANUFACTURER

MISCELLANEOUS MASONRY OPENING

MSW MASONRY SHEAR WALL MEAN SEA LEVEL

METAL

NTS NOT TO SCALE

NUMBER

NEAR SIDE

LNTL LINTEL

JOIST

JOINT

HOLLOW STRUCTURAL SECTION

HORIZ HORIZONTAL

EXPANSION JOINT

DOWEL

EACH

DEEP LEG TRACK

CTR CENTER

CTR'D CENTERED

CONST CONSTRUCTION

CAISSON

BUILT UP COLUMN

CENTER TO CENTER

COLD FORMED STEEL

CONSTRUCTION JOINT

CONCRETE MASONRY UNIT

CONTROL AND/OR

BRICK

BEARING PLATE

BUILDING

BLDG

BLK

BLW

BOTT

BRG

BSMT

BUC

C/C

CAIS

CFS

CLR

CMU

COL

DIA

DIM

DLT

DO

DN

DTL

DWL

FΑ

EF

ENG

ELEV

EOS

EQ

ES

FW

EXP

FXT

FD

FDN

FIN

FLR

FLG

FS

FTG

GALV

GΑ

GC

GL

GR

HC

HD HGT

HI

HS

ID

INT

INV

JST JT

KO LB

LDG

MAS

MAT'L

MAX

MFR

MIN

MO

MSL MTL

NO

NS

MISC

LG

LL

HK

DIAG

BRK

BM

BALANCE

BOND BEAM

BACK TO BACK

BOTTOM CHORD

ASTM AMERICAN SOCIETY OF

TESTING MATERIALS

AMERICAN WELDING SOCIETY PT

ARCH ARCHITECT

ADH

AMERICAN CONCRETE INSTITUTE)C

ARCHITECTURALLY EXPOSED OPNG OPENING

ABOVE

OUT TO OUT

ON CENTER

OVER HEAD

OPPOSITE

PRECAST

PLATE

PANEL

PROJECTION

PARTITION

ROOF DRAIN

REFERENCE

RADIUS

RETURN

SECTION

SHEET

SIMILAR

SI OPED

SPACE(S)

SPECS SPECIFICATIONS

SQUARE

STD STANDARD STIFF STIFFENERS

STRUCT STRUCTURAL

SYMM SYMMETRICAL

T&B TOP AND BOTTOM

TIE BEAM

THICK

THR'D THREADED

TRANS TRANSVERSE

WITH

WOOD

WEIGHT

TOP'G TOPPING

TYP TYPICAL

VERT VERTICAL

THKS THICKENED SLAB

TOTAL LOAD

TOP CHORD

TEMPERATURE

TRENCH FOOTING

UNO UNLESS NOTED OTHERWISE

WINDOW OPENING (MASONRY)

VERIFY IN FIELD

WORKING POINT

ELEVATION TOP AND BOTTOM OF LIST

"ELEVATION, TOP OF"

"ELEVATION, BOTTOM OF"

WWF WELDED WIRE FABRIC

T/BB TOP OF BOND BEAM

T/CONC TOP OF CONCRETE

T/F TOP OF FOOTING

T/MAS TOP OF MASONRY

T/LDG TOP OF LEDGE

T/P TOP OF PIER

T/SLAB TOP OF SLAB

T/W TOP OF WALL

T/STL TOP OF STEEL

T/GB TOP OF GRADE BEAM

B/F BOTTOM OF FOOTING

PLUS OR MINUS

ELEVATION

DIAMETER

T/CAIS TOP OF CAISSON

SPECIAL CHARACTERS

DEGREE

B/PL BOTTOM OF PLATE

T/BM TOP OF BEAM

STL STEEL

RTU ROOF TOP UNIT

SCHED SCHEDULE

REQ'D REQUIRED

PLYWD PLYWOOD

OPP HD OPPOSITE HAND

OUTSIDE DIAMETER

OSB ORIENTED STRAND BOARD

OUTSTANDING LEG

POWDER ACTUATED FASTENER

POUNDS PER LINEAR FOOT

POUNDS PER SQUARE FOOT

POUNDS PER SQUARE INCH

PARALLEL STRAND LUMBER

PRESSURE TREATED

REINF REINFORCE(D) (ING) (MENT)

REVISION/REVISED

ROUGH OPENING

RETAINING WALL

SAWCUT JOINT

STAINLESS STEEL

STEEL JOIST INSTITUTE

SHORT SLOTTED HOLES

TONGUE AND GROOVE

TOP CHORD EXTENSION

ROOF RELIEF DRAIN

OVERSIZE HOLE

OUTSIDE FACE

OVERALL

OF

OPP

OSL

OVS

PAF

PC

PLF

PNL

PSF

PSI

PSL

PTN

RD

REF

RO

RRD

RTN

RW

SECT

SHT

SIM

SJI

SPA

SQ

SSL

T&G

TC

TF

TCX

TEMP

THK

TL

VIF

w/


WD

WO

WP

WT

PROJ




No.
860325
STATE OF

WD I ANA

₹≧∐ ●●●●●


Sheet S402
Date 2020/04/21
Project Number 990433-10705



KLS

ACV


CRM



KLS ACV Assurance: CRM

\$600

2020/04/21 990433-10705



P.4 TOOLED SLAB JOINTS AT 1/3 POINTS OF OVERALL SLAB DIMENSION TYPICALLY

Building Area (NEW) = 1,764 s.f. x 2 square feet square feet

Picnic Shelters: A-3 Occupancy [303.4]

Type V-B Construction permitted based upon allowable area.

6,000 square feet [Table 503] +4,500 square feet [506.2]

1,762 square feet each


HAMILTON


CONSULTANTS

SFM

As indicated


2020/04/21





PERGOLA SECTION

3/16" = 1'-0"



3 TRANSVERSE PERGOLA SECTION
3/8" = 1'-0"

NOTE: ALL PREFINISHED STEEL PERGOLA COMPONENTS ARE FURNISHED & INSTALLED BY THE SHELTER MANUFACTURER

No. AR00880096 CMT SFM


CONSULTANTS

Approver


As indicated

2020/04/21


CONSULTANTS 1/4'' = 1'-0'' 2020/04/21 990433-10705



1 ALTERNATE: CONCRETE SLAB FINISH PLAN
1/4" = 1'-0"



2020 4.53:49 PM



D. INSTALL SUSPENDED CEILING GRID WITH EQUAL SIZE PANELS AT EACH SIDE OR END OF THE INDIVIDUAL SPACES UNLESS OTHERWISE INDICATED. NO PANEL SHALL BE LESS

E. THE ARCHITECTURAL REFLECTED CEILING PLAN SHALL GOVERN THE LAYOUT OF ALL CEILING ELEMENTS AND/OR PENETRATIONS. COORDINATE ANY FIELD VERIFIED OR AS-BUILT CONDITIONS THAT DIFFER FROM WHAT IS SHOWN ON THESE PLANS WITH THE

F. SIZES AND SHAPES OF LIGHTING FIXTURES AND OTHER MISCELLANEOUS ELECTRICAL

COORDINATE ACTUAL SIZES AND TYPES WITH MECHANICAL DRAWINGS/ENGINEER.

I. ALL CEILING MOUNTED ITEMS (SPRINKLER HEADS, MOUNTING MECHANISMS, ETC.) SHALL BE CENTERED IN THE CEILING PANELS UNLESS OTHERWISE NOTED/INDICATED.

C.1 PREFINISHED STEEL SHELTER STRUCTURE PROVIDED BY SHELTER SUPPLIER C.2 EXPOSED 2 X 6 T&G WOOD DECK WITH FACTORY APPLIED CLEAR FINISH

C.3 PREFINISHED GUTTER & DOWNSPOUT PROVIDED BY SHELTER SUPPLIER C.4 PREFINISHED STRUCTURLA STEEL PURLINS PROVIDED BY SHELTER SUPPLIER

G. COORDINATE CLEARANCES WITH M.E.P. DRAWINGS. NOTIFY ARCHITECT OF

H. SIZES OF MECHANICAL EQUIPMENT (IF SHOWN) ARE FOR REFERENCE OLY.

CEILING PLAN KEYNOTES

EQUIPMENT (IF SHOWN) ARE FOR REFERENCE ONLY. COORDINATE ACTUAL SIZES AND

OR WHERE INDICATED. COORDINATE LOCATION WITH ARCHITECT.

C. ALL CEILING HEIGHTS ARE FROM FINISHED FLOOR.


TYPES WITH THE ELECTRICAL DRAWINGS/ENGINEER.

CONFLICTS PRIOR TO CONSTRUCTION.

PROVIDED BY SHELTER SUPPLIER


1/8" = 1'-0"


A201 2020/04/21 990433-10705




1 FIRST FLOOR - REFLECTED CEILING PLAN

1/8" = 1'-0"







ELECTRICAL ABBREVIATIONS

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
RMC	RIGID METALLIC CONDUIT	OC	ON CENTER	MCC	MOTOR CONTROL CENTER	JB	JUNCTION BOX	FLUOR	FLUORESCENT	DPST	DOUBLE POLE SINGLE THROW	С	CONDUIT	#	NUMBER
RVS	REVERSE	OD	OUTSIDE DIAMETER	MCM	THOUSAND CIRCULAR MILS			FT	FOOT/FEET	DTL	DETAIL	CAB	CABINET	2SP	2 SPEED
SCIC	SPECIAL COMMUNICATIONS INTERFACE CAB.	Р	POLE	MCP	MOTOR CURRENT PROTECTOR	KA	KILOAMPERES	GALV	GALVANIZED	DWG	DRAWING	СВ	CIRCUIT BREAKER	Α	AMPERE (AMPS)
SEC	SECONDARY	PA	PUBLIC ADDRESS ——	MECH	MECHANICAL	KCMIL	THOUSAND CIRCULAR MILS	GENR	GENERATOR	EX	EXISTING	CCTV	CLOSED CIRCUIT TELEVISION	AC	ALTERNATING CURRENT
SHT	SHEET	PAR	PERSONAL ALARM RECEIVER	MFR	MANUFACTURER	KEC	KITCHEN EQUIPMENT CONTRACTOR	GFI	GROUND FAULT INTERRUPTER	(ER)	EXISTING RELOCATE	CKT	CIRCUIT	A/C	ABOVE COUNTER
SN	SOLID NEUTRAL	РВ	PULL BOX	МН	MANHOLE/METAL HALIDE	KV	KILOVOLT	GFR	GROUND FAULT RELAY	ELEC	ELECTRIC/ELECTRICAL	CLG	CEILING	ACCP	ACCESS PANEL
SPST	SINGLE POLE SINGLE THROW	PF	POWER FACTOR	MIN	MINIMUM	KVA	KILOVOLT AMPERES	GRD	GROUND	EMER	EMERGENCY	СО	CONDUIT ONLY	AF	AMPS-FRAME
SSC	SOUND SYSTEM CABINET	PH, O/	PHASE	MOM	MOMENTARY	KW	KILOWATT	НН	HANDHOLE	EMT	ELECTRICAL METALLIC TUBING CONDUIT	COMM	COMMUNICATIONS	AFF	ABOVE FINISHED FLOOR
STD	STANDARD	PNL	PANEL	MT	EMPTY	KWH	KILOWATT HOURS	HID	HIGH INTENSITY DISCHARGE	ENCL	ENCLOSURE	CONTR	CONTRACTOR	AFG	ABOVE FINISHED GRADE
SW	SWITCH	PRI	PRIMARY	MTD	MOUNTED	LCL	LONG CONTINUOUS LOAD	HOA	HAND-OFF-AUTOMATIC	EQ	EQUAL	CRT	CATHODE RAY TUBE (MONITOR)	AIC	AMP INTERRUPTING CURRENT
SWBD	SWITCHBOARD	PT	POTENTIAL TRANSFORMER	MTG	MOUNTING	LRA	LOCKED ROTOR AMPS	HP	HORSEPOWER	EQUIP	EQUIPMENT	СТ	CURRENT TRANSFORMER	AT	AMPS-TRIP
SYM	SYMMETRICAL	PVC	POLYVINYL CHLORIDE DUCT	(N)	NEW	LT	LIGHT	HPS	HIGH PRESSURE SODIUM	EST	ESTIMATE	CU	COPPER	ATS	AUTOMATIC TRANSFER SWITCH
T	THROW	PWR	POWER	NC	NORMALLY CLOSED	LTG	LIGHTING	HV	HIGH VOLTAGE	EWC	ELECTRIC WATER COOLER	CW	COOL WHITE	AUTO	AUTOMATIC
TP	TWISTED PAIR	(R)	REMOVE	NF	NON-FUSED	LV	LOW VOLTAGE	HZ	HERTZ	FACP	FIRE ALARM CONTROL PANEL	CX	COAXIAL CABLE	AWG	AMERICAN WIRE GAUGE
TPS	TWISTED PAIR SHIELDED	(RR)	REMOVE AND RELOCATE	NIC	NOT IN CONTRACT	MATV	MASTER ANTENNAE TELEVISION	ID	INSIDE DIAMETER	(F)	FUTURE	DF	DRINKING FOUNTAIN	BIL	BASIC IMPULSE LEVEL
ттв	TELEPHONE TERMINAL BOARD	REQD	REQUIRED	NL	NIGHT LIGHT	MAX	MAXIMUM	IMT	INTERMEDIATE METAL TUBING	F	FUSED	DGP	DATA GATHERING PANEL	BLDG	BUILDING
TTC	TELEPHONE TERMINAL CABINET	RM	ROOM	NO	NORMALLY OPEN/NUMBER	MC	MOTOR CONTROLLER	INC	INCANDESCENT	FA	FIRE ALARM	DIA	DIAMETER	BFG	BELOW FINISHED GRADE
TY	TRANSFORMER	RMS	ROOT MEAN SQUARE	NOR	NORMAL			IV	INVERT ELEVATION	FLA	FULL LOAD AMPS	DP	DOUBLE POLE		
TYP	TYPICAL	-	. 1001 MEAN OGO, WE	NTS	NOT TO SCALE			. v		FLEX	FLEXIBLE METAL CONDUIT	DPDT	DOUBLE POLE DOUBLE THROW		

UNDERGROUND

VOLTAMPERES

WATT HOUR METER WEATHERPROOF WATERTIGHT WARM WHITE EXPLOSION PROOF

VOLT

UNLESS OTHERWISE NOTED

UNINTERRUPTIBLE POWER SYSTEM

	PWR POWER NC (R) REMOVE NF	NORMA NON-FI	ALLY CLOSED LTG LIGHTING USED LV LOW VOLTAGE	HV HZ	THE TYPE THE TYPE THE TYPE THE TYPE THE TYPE TYPE THE TYPE TYPE TYPE TYPE TYPE TYPE TYPE TYP	WATER COOLER RM CONTROL PANEL	CW CX	COOL WHITE COAXIAL CABLE	AUTO AWG																
	(RR) REMOVE AND RELOCATE NIC		CONTRACT MATV MASTER ANTENNAE TELEVISIO		INSIDE DIAMETER (F) FUTURE	WOONTHOLTANEE	DF	DRINKING FOUNTAIN	BIL																
	REQD REQUIRED NL RM ROOM NO	NIGHT NORM	LIGHT MAX MAXIMUM ALLY OPEN/NUMBER MC MOTOR CONTROLLER	IMT INC	INTERMEDIATE METAL TUBING F FUSED INCANDESCENT FA FIRE ALAF	RM	DGP DIA	DATA GATHERING PANEL DIAMETER	BLDG BFG																
	RMS ROOT MEAN SQUARE NOR	NORMA	AL	IV	INVERT ELEVATION FLA FULL LOAI	D AMPS	DP	DOUBLE POLE DOUBLE TUROW																	
	NTS	NOT TO	O SCALE			METAL CONDUIT	DPDT	DOUBLE POLE DOUBLE THROW																	
			ELECTRICAL	<u>SYMBO</u>	OL LEGEND (NOTE: ALL SYMBOLS MAY NOT BE USED)																				
	POWER		LIGHTS		FIRE		N	IURSE CALL																	
ø	DUPLEX RECEPTACLE SPLIT WIRED	0	SURFACE MOUNTED OR RECESSED LED FIXTURE	0	IONIZATION SMOKE	N DS	NURSE CALL, DUTY STATION																		
•	RECEPTACLE SPECIAL, NEMA CONFIGURATION	Ю	WALL MOUNTED LED FIXTURE	H	THERMAL DETECTOR 135° FIXED	N SE	NURSE CALL, STAFF EMERGENCY																		
•	FLUSH FLOOR OUTLET		SURFACE/RECESSED 1 x 4 LED LIGHT FIXTURE	P	PHOTO DETECTOR PHOTO ELECTRIC	N SEL	NURSE CALL, SATELLITI	E EQUIPMENT LAB																	
∇Ф▼	FLUSH FLOOR BOX, THREE GANG		SURFACE/RECESSED 2 x 4 LED LIGHT FIXTURE	F	PULL STATION	N SPS	NURSE CALL, SATELLITE POWER SUPPLY																		
BAT	EMERGENCY BATTERY UNIT	•	PHOTOCELL	+	STROBE UNIT 30CD	N MPS	NURSE CALL, MASTER F	POWER SUPPLY																	
Φ	RECEPTACLE, SINGLE	8	EXIT LIGHT FIXTURE CEILING MOUNTED	§ ^D	FIRE ALARM, IONIZATION DUCT DETECTOR	N POW	NURSE CALL, POWER S	UPPLY																	
Φ	RECEPTACLE, DUPLEX	⊢⊗	EXIT LIGHT FIXTURE WALL MOUNTED	© co	COMBINATION PHOTOELECTRIC AND CARBON MONOXIDE DETECTOR	N DLZ	NURSE CALL, DOME LIGHT, ZONE LIGHT																		
©	RECEPTACLE CEILING MOUNTED, DUPLEX		LIGHT FIXTURE CONNECTED TO EMERGENCY POWER	F.A.C.P.	FIRE ALARM CONTROL PANEL	N DLSL	NURSE CALL, DOME LIG	HT, SINGLE LAMP																	
#	RECEPTACLE, QUADPLEX	29	BATTERY OPERATED EMERGENCY LIGHT - WALL MOUNTED	FAAP	FIRE ALARM ANNUNICATOR PANEL	N DLDC	NURSE CALL, DOME LIGHT, DUAL LAMP																		
€WP	RECEPTACLE, DUPLEX WEATHERPROOF ('WHILE-IN-USE' TYPE)	POLE MOUNTED LIGHT FIXTURE - SINGLE HEAD		\Diamond	FIRE ALARM, TAMPER SWITCH	N DLQL	NURSE CALL, DOME LIGHT, QUAD LAMP																		
ФЕ	RECEPTACLE ON EMERGENCY CIRCUIT, RECEPTACLE AND PLATE SHALL BE RED	¤	SURFACE / RECESSED LED FIXTURE		FIRE ALARM, FLOW SWITCH	N DLCI	NURSE CALL, DOME LIGHT WITH COUPLER INTERFACE																		
Ø⊺L	RECEPTACLE, DUPLEX, EMERGENCY RED TWIST LOCK	ŀ¤	WALL MOUNTED LED FIXTURE	E4	HORN STROBE	NURSE	NURSE CALL, CENTRAL EQUIPMENT CABINET																		
Φ ^{GFI}	RECEPTACLE, DUPLEX, GROUND FAULT CIRCUIT INTERRUPTER		BOLLARD LIGHT FIXTURE		FIRE ALARM, SPEAKER	N H CB																			
Φ ^{USB}	USB RECEPTACLE	Ø	FLOOD LIGHT GROUND MOUNTED		FIRE ALARM, SPEAKER STROBE	N PS																			
•	DOORBELL PUSH BUTTON		SWITCHES		COMMUNICATION / SECURITY	N SS	NURSE CALL, STAFF STA	ATION																	
	DOOR BELL CHIME	\$	\$ SWITCH, SINGLE POLE		TELEPHONE OUTLET BOX AND COVER PLATE	N DLB	NURSE CALL, CODE BLUE DOME LIGHT																		
TLV	TRANSFORMER, 120V TO LOW VOLTAGE	\$ ₃	\$ ₄	\$ ₄	\$ ₄	SWITCH, THREE-WAY	▼ P	TELEPHONE OUTLET BOX, AND COVER PLATE, PUBLIC	N	NURSE CALL, FOOT OPE	RATED CALL SWITCH														
s v-	SECURITY ALARM POINT DOOR SWITCH						<u> </u>				· ·					· .			<u> </u>				SWITCH, FOUR-WAY	-	TELEPHONE OUTLET FLOOR BOX WITH COVER PLATE
S	SECURITY DOOR LOCK RELEASE - ELECTRIC STRIKE	- \$ _D	SWITCH, DIMMER	▼	TELEDATA OUTLET		HOMERUN																		
S	SECURITY MOTION DETECTOR	- \$ DS	SWITCH, DOOR SECURITY	P	TELEDATA OUTLET FLOOR BOX WITH COVER PLATE	or																			
s	SECURITY ALARM BELL	- \$k 	SWITCH, KEYED	-	DATA OUTLET		WIRING CONCEALED U	NDER OR IN FLOOR																	
©	CLOCK OUTLET	\$p 	SWITCH, PILOT LIGHT	<u> </u>	SPEAKER, FLUSH CEILING MOUNTED	B	WIRING EMERGENCY																		
© _c	CLOCK OUTLET WITH CONTROL STATION	- \$a 	SWITCH, CONTROLLING FIXTURES MARKED WITH a	, HS	SPEAKER, WALL MOUNTED	A• C	A= GROUND; B= NEUTRAL; C= HOT																		
©J	TELEVISION OUTLET (RG6)	\$т	SWITCH, MANUAL TIMER		SPEAKER HORN TYPE, WALL MOUNTED		WIRING TURNED UP																		
(JUNCTION BOX 4 11/16 x 4 11/16 x 2 1/8" UNLESS NOTED OTHERWISE	- \$ ₁₁	TT SWITCH FOR MOTORS 1/2HP OR SMALLER	PA SOUND SYSTEM AMPLIFIER			• WIRING TURNED DOWN																		
MDP	MAIN DISTRIBUTION OR POWER PANELBOARDS		PUSH BUTTON CONTROL STATION	— ⊢©	INTERCOMM HANDSET		WIREMOLD APENDED N	OTE DENOTES TYPE																	
	FLUSH OR SURFACE MOUNTED BRANCH PANELBOARDS 120/280V	••	PUSH BUTTON "UP-DOWN-DN"	H© M	INTERCOMM MASTER PANEL		CABLE TRAY																		
♦	ELECTRICAL MOTOR CONNECTION - VERIFY HP, AND PHASE		PANIC BUTTON	— ICPS	INTERCOMM SYSTEM POWER SUPPLY	——————————————————————————————————————	HEAT TRACE CABLE																		
	DISCONNECT SWITCH FOR MOTORS OVER 1/2HP	D(MOTION DETECTOR	A	DEMO: POINT WHERE EXISTING TO REMAIN STOPS AND DEMOLITION BEGINS	K	CARD KEY ACCESS CON	NTROL																	
\boxtimes	MOTOR CONTROLLER WITH AUX CONTACTS HOA, PB, PILOT AND CONTROL TRANSFORMER.	GB	SECURITY GLASS BREAK DETECTOR	K	REVISED: POINT WHERE NEW WORK CONNECTS TO EXISTING TO REMAIN CARD KEY ACCESS DEVICE	-¢-	CEILING MOUNTED FIR	E ALARM HORN / STROBE																	
: (a)	TELEVISION OUTLET (RG6 AND 2-CAT6) LOW VOLTAGE ULTRASONIC CEILING SENSOR 'SCHNEIDER	<u></u>	SINGLE CIRCUIT PIR WALL SENSOR 'SCHNEIDER ELECTRIC' #SLSPWS1277UX(COLOR).		SECURITY CAMERA SECURITY CAMERA	9		MOUNT PIR OCCUPANCY SENSOR SENSOR); 'SCHNEIDER ELECTRIC'																	
\sim	ELECTRIC' #SLSCUS2000 (SENSOR); 'SCHNEIDER ELECTRIC' #SLSPP1277 (POWER PACK)	@ ²	DUAL CIRCUIT PIR WALL SENSOR 'SCHNEIDER ELECTRIC' #SLSPWD1277UX(COLOR).		/ (360°) (360°)	₽/T	LOW VOLTAGE CEILING M	MOUNT DUAL-TECHNOLOGY OCCU SLSCDT2000 (SENSOR); 'SCHNEID																	






ELECTRICAL SYMBOLS & ABBREVIATIONS

HAMILTON COUNTY PARKS

CLAY TOWNSHIP CHILDREN'S PAVILION AT COXHALL

2000 W. 116TH STREET, CARMEL, IN 46032



Quality Assurance: DH

AS SHOWN

E001 04/21/2020

PANEL: 'RR' (EXIST.)			VOLTS: 120/240 AMPS: 225 CKTS: 42					PHA	SE: 1		PROVIDE:
LOCATION: REST ROOM	BLD	G							E: 3 D: BC	NOTTOM	
REMARKS	<lc ØA</lc 	AD> ØB	POLE	CIR. NO.		CIR. NO.	POLE	<loa ØA</loa 	AD> ØB		REMARKS
EXIST. LOAD			25 / 2	1 3		2	25				EXIST. LOAD
EXIST. LOAD			35 <u>2</u>	5 7		6 8	20				EXIST. LOAD
EXIST. LOAD EXIST. LOAD			20 20	9		10 12	25				EXIST. LOAD
EXIST. LOAD			20	13		14	20			E	XIST. LOAD
EXIST. LOAD			20	15		16	20			E	XIST. LOAD
EXIST. LOAD			20	17		18	20				SPARE
NEW BOLLARD LTG			20	19		20	20				SPARE
NEW WALL SCONCE LTG			20	21		22	20				SPARE
NEW RECEPTS - SHELTER			20	23		24	20				SPARE
NEW RECEPTS - SHELTER			20	25		26	20				SPARE
PHOTOCELL			20	27		28	20				SPARE
SPARE			20	29		30	20				SPARE
SPARE			20	31		32	20				SPARE
SPARE			20	33		34	20				SPARE
SPARE			20	35		36	20				SPARE
SPARE			20	37		38	20				SPARE
SPARE			20	39		40	20				SPARE
SPARE			20	41		42	20				SPARE


	CONDUIT TYPE									
CONDUIT LOCATION OR APPLICATION	RIGID	INTERMEDIATE	E.M.T.	FLEXIBLE	FLEXIBLE W/ W.P. JACKET	P.V.C. SCHED 40	A.C. CABLE			
IN CONCRETE SLAB (NOT LARGER THAN 1"C)		3								
BELOW LOWEST FLOOR SLAB		3				2				
CONCEALED IN WALLS, ABOVE CEILINGS AND IN FURRED SPACES		3	1							
INSIDE, ABOVE BOTTOM OF ROOF STEEL							\bigcirc			
FEEDER, POWER AND SIGNAL CIRCUITS RUN EXPOSED	3	3								
FINAL CONNECTION TO EQUIP. SUBJECT TO VIBRATION				\bigcirc						
FINAL CONNECTION TO EQUIP. IN DAMP LOCATIONS										
SHORT CONNECTIONS WHERE NON-FLEXIBLE CONDUIT IS IMPRACTICAL										

— TYPE OF CONDUIT TO BE USED.

(1) – E.M.T. SHALL NOT BE USED IN SIZES LARGER THAN 2 INCH.


 $\left(2
ight)$ — CONVERT TO RIGID OR INTER. THROUGH SLAB.


 $\binom{3}{}$ – USE THREADED FITTINGS ONLY.



OPERABLE DEVICE MOUNTING HEIGHT DETAIL

NOT TO SCALE





2. REFER TO SPECIFICATION SECTION 26 56 00 FOR MOUNTING AND

CONSULTANTS



亡 🚡 •••••



ELECTRICAL DETAILS & SCHEDULES
HAMILTON COUNTY PARKS

J. SNOON NO. No. SS 17006 STATE OF MOLANA MOLANA MOLANA MOLANA MOLANA MOLANA

JS

DH AS SHOWN

E002 04/21/2020


20007

LEVELING REQUIREMENTS.

- I. PROVIDE CONCRETE BASE FOR ALL TYPE 'B' BOLLARD LIGHT FIXTURES. SEE DETAIL C4/E002.
- 2. MINIMUM CONDUIT SIZE SHALL BE I"C. MINIMUM CONDUCTOR SIZE SHALL BE #10.

***** KEYED PLAN NOTES

- I. ALTERNATE #I PROVIDE ADDITIONAL PRICE TO THE BASE BID TO ADD TWO (2) TYPE 'B' BOLLARD LIGHTS FOR THE NEW PERGOLA.
- 2. INSTALL BRANCH CIRCUITS FOR RECEPTACLES AND WALL PACKS INSIDE NEW COLUMNS.
- 3. PROVIDE PHOTOCELL FOR CONTROL OF TYPE 'A' AND 'B' LIGHT FIXTURES. MOUNT AS HIGH AS POSSIBLE BELOW EAVE OF SHELTER. PHOTOCELL SHALL BE SIMILAR YO 'YORK' #2001.






GENERAL KEYED PLAN NOTES


CONSULTANTS














BRANCH CIRCUITS FOR FEEDS TO SHELTER. EACH BRANCH CIRCUIT SHALL 2-#IO, I-#IO GND IN A I"C.

SITE PLAN - ELECTRICAL

SCALE: 1"= 20'-0"



SITE PLAN - ELECTRICAL
HAMILTON COUNTY PARKS



ΒZ

JS DH

as shown



ELECTRICAL SPECIFICATIONS:

1.0 GENERAL

- 1.1 All materials shall be as specified and approved by Underwriters Laboratories.
- 1.2 Provide a complete electrical system conduit system as indicated herein and/or on the drawings. The latest edition of The National Electric Code shall be the Minimum requirement for all work.
- 1.3 Any substitutions to manufacturers of equipment listed in these specifications must be approved in writing by the Owner's Engineer.
- 1.4 E.C. shall submit shop drawings of electrical switchgear to Architect/Engineer for review.
- 1.5 Shop drawings shall include: A. Single line riser diagram of electrical system. B. Completed schedules for all electric panels.
- 1.6 Drawings and Specifications: It shall be the Contractor's duty to examine and have thorough knowledge of the architectural, structural, electrical, mechanical and site work Drawings and Specifications.
- 1.6.1 The commencement of work under this Section indicated that the Contractor has examined and has knowledge of the architectural, structural, electrical, mechanical and site work Drawings and Specifications. The failure of the Contractor to acquaint himself with all available information shall not relieve him of any responsibility for performing his work properly.
- 1.6.2 No additional compensation shall be allowed because of conditions that occur due to the Contractor's failure to become thoroughly familiar with all of the Contract Documents for this project, as described above, and with the job site.
- 1.6.3 It shall be the Contractor's duty to notify the Architect and/or Engineer, in a timely manner, of any discrepancies, errors, omissions, ambiguities, or conflicts which were known or discovered during the course of the preparation of the bid or the conduct of
- 1.6.4 Unless expressly stipulated, no additional allowance will be made in the Contractor's and/or manufacturer's favor by virtue of errors, ambiguities and/or omissions which were known to or which should have been known or discovered during the preparation of the bid estimate and directed to the Architect and \ or Engineer's attention in a timely
- 1.6.5 The Drawings and Specifications are intended to supplement one another. Any materials or labor called for in one but not the other shall be furnished as if both were mentioned in the Specifications and shown on the Drawings. Labor and/or materials neither shown nor specified, but necessary for the completion and proper functioning of the systems, shall be furnished and installed by this Contractor.
- 1.6.6 The Drawings are diagrammatic and are intended to depict the approximate locations of equipment, piping and apparatus. Dimensions given on the Drawings, in figures, shall take precedence over scaled dimensions. All dimensions, whether in figures or scaled, shall be verified in the field.
- 1.6.7 The plans show the arrangement of all fixtures, equipment and material and are not intended to show all details. Each and every accessory intended for the purpose of execution of the work is understood to be part of the work.
- 1.6.8 The location of equipment and pipe, as shown on the Drawings, is diagrammatic and schematic and it is the responsibility of the Contractor to make his own fabrication and installation drawings and layouts to eliminate all structural and other physical interferences without detriment to the structural, mechanical and architectural components of the building. The Contractor must organize the physical arrangement of the systems of material in the confines of the space in order for them to function and perform in accordance with the intent of the design. The Contractor is not responsible for the design performance; he is responsible for the development of installation and fabrication drawings for the installation of his equipment and material within the available spaces.
- 1.6.9 The Contractor shall carefully verify all measurements at the site, determine the exact location of all chases, openings, plenums and ceiling cavities required by his work and shall furnish and set all sleeves, inserts and hangers as required for the work herein. The Contractor shall verify actual job dimensions before fabrication of any materials, purchasing or installation of equipment.
- 1.7 Space Conditions: It shall be the Contractor's responsibility to verify that all apparatus, gear, fixtures, conduit, etc, shall fit into that available spaces in the building and must be introduced into the building at such times and in such manner as not to cause damage to the structure.

- 1.7.1 Where minor deviations from plans are required in order to conform to space limitations, such changes shall be made by the Contractor at no additional cost to the Owner and shall be subject to the approval of the Architect and/or Engineer.
- 1.7.2 All equipment normally requiring service shall be easily accessible.
- 1.8 Coordination and Conflicts: The Contractor shall coordinate his work so that it does not interfere with the work of other trades. It shall be the Contractor's responsibility to see that his work is installed in a timely manner.
- 1.8.1 In the event that there is a discrepancy or conflict in the plans or Specifications it shall be the Contractor's responsibility to notify the Architect and/or Engineer of this conflict or discrepancy prior to his acceptance of the project. Unless expressly stipulated, no additional allowance will be made in the Contractor's and/or Manufacturer's favor by virtue of errors, ambiguities and/or omissions which were known to or which should have been known or discovered during the presentation of the bid estimate and directed to the Architect's and/or Engineer's attention in a timely manner.
- 1.9 Guarantee: All equipment shall be started, tested, adjusted and placed in satisfactory operating condition by the Contractor. All equipment shall be covered for the duration of the Manufacturer's guarantee or warranty and the Contractor shall furnish the Owner with all Manufacturer's quarantee warranties.
- 1.9.1 Guarantee all work, materials and equipment for a period of one (1) year from date of acceptance by the Owner's Engineer. The Guarantee shall include full service adjustments, repairs and replacement parts at no expense to Owner, and to the complete satisfaction of the Owner's Engineer.
- 1, 9, 2 The Contractor shall furnish a letter addressed to the owner outlining the year's guarantees and advising that the completed systems have been installed in accordance with Plans and Specifications and that they are in proper operating condition.
- 1.10 Inspection Authority Certificate of Approval shall be furnished the Owner's Engineer before final acceptance will be given.
- 1. 10. 1 Provide any inspections and certificates required by local jurisdictional authorities to obtain acceptance of the specified equipment and the installation.
- 1.11 Submittals: Contractor agrees that Shop Drawing Submittals processed by the Engineer are not Change Orders; that the purpose of Shop Drawing Submittals by the Contractor is to demonstrate to the Engineer that the Contractor understands the design concept, that he demonstrates his understanding by indicating which equipment and materials he intends to furnish and install and by detailing the fabrication and installation methods he intends to use.
- 1.11.1 The Contractor further agrees that if deviations, discrepancies or conflicts between Shop Drawings and Specification are discovered either prior to or after Shop Drawing Submittals are processed by the Engineer, the design Drawings and Specifications shall control and shall be followed.
- 1.11.2 Where shop drawings are reviewed, said review does not in any way relieve the Contractor from the responsibility nor the necessity of furnishing material or performing work required by the Contract Drawings and Specifications.
- 1.11.3 Submittal review is considered as general acceptance of the basic applicability of the equipment. Contractor is responsible for the installation of any substituted equipment within a given space. When the Contractor desires to use substituted equipment, he shall be responsible for producing his own coordinated working drawings which depict the substituted equipment accommodated in the space. Where the substituted equipment creates the need for alterations in any portion of the work depicted in the contract documents, it shall be the Contractor's responsibility to notify all of the affected parties and coordinate these items with all other trades. Further, it shall be the Contractor's responsibility to assume any additional cost to the Contract created by the substituted equipment.
- 1.11.3.1. Substituted equipment is any equipment which deviates from the equipment specified herein, as the first named manufacturer or the equipment scheduled on the plans.

6.0 Method of Wiring

- 6.1 Conduit raceways shall be used for installation of all wiring where indicated on drawings.
- 6.1.1 Exposed conduit subject to mechanical injury shall be either full weight rigid steel (heavy-wall) type or intermediate metal conduit (I.M.C.) - Any conduits run in the mechanical room or electrical room not concealed in partitions, above finished ceilings or under the floor slab are considered exposed to mechanical injury. Either type shall have galvanized or equal finish. Conduit run exposed and not subject to mechanical injury, concealed above ceiling or in furred spaces may be electrical metallic tubing (E. M. T.) with galvanized or equal finish Aluminum conduit shall not be used in concrete or masonry, but is permitted for use where exposed and not subject to mechanical injury or where concealed above ceiling or in furred spaces. Conduit joints shall be made with standard conduit couplings, (no running-threads) cadmium plated. Schedule 40 PVC conduit is also permitted for use in masonry or concrete. Any feeder conduits which are PVC must be buried beneath the floor slab - not in the concrete. Any exposed conduit projections out of concrete slab must be changed to rigid steel or I.M.C. at the surface of the slab. Rigid steel or I.M.C. conduit is required in concrete or masonry Construction.
- 6.1.2 Conduit shall not be smaller than 3/4" nominal trade size, except for switch legs or where expressly noted.
- 6.1.3 Install all conduits as near bottom chord of joists as practical. All conduits must be securely fastened and adequately supported. Perforated straps will not be permitted. All suspended conduits must be supported on a trapeze using "Unistrut" and bolted hanger construction. Conduits supported using suspended ceiling system (either tee bars or hanger wires) will not be permitted.
- 6.1.4 All conduit sizing for branch circuits shall be based on the use of Type THW code grade insulation. This method of sizing shall be used regardless of insulation type used in the conduit.
- 6.1.5 All conduits shall be concealed.
- 6.1.6 Pull boxes and junction boxes shall be installed where indicated on the drawings or where required to facilitate wire installation.
- 6.1.7 Cutting of structural concrete or steel to facilitate wiring installation will not be permitted without written approval of the Owner's Engineer.
- 6.1.8 All exposed conduit shall be run rectilinear with building construction using concentric bends.
- 6.1.9 Control circuit conduits (w/pull wires) under floor and in ceiling shall be as shown on drawings or as required.

CONSULTANTS

1 •••••



JS DH

AS SHOWN

E30 04/21/2020